

**IRVINE RANCH WATER DISTRICT
WASTE DISCHARGE PRETREATMENT
AND
SOURCE CONTROL PROGRAM**

**An Ordinance Repealing Ordinance No. 2015-1 and
Adopting Regulations for
the Discharge of Wastewater to Sewerage Facilities of
the Irvine Ranch Water District Tributary to
the South Orange County Wastewater Authority**

(Pretreatment Ordinance)

ORDINANCE 2020-1

Adopted November 23, 2020

Irvine Ranch Water District

15600 Sand Canyon Avenue Irvine, California 92618

irwd.com

Table of Contents

<u>Section</u>		<u>Page</u>
ARTICLE 1		
GENERAL PROVISIONS		
1.01	Introduction	5
1.02	Objectives	5
1.03	Purpose	6
1.04	Policy	7
1.05	Applicability	7
1.06	Availability of Sewerage Facilities	7
1.07	Notice to Employees.	8
ARTICLE 2		
DEFINITIONS AND ABBREVIATIONS		
2.01	Definitions Contained in Publication	8
2.02	Definition of Terms	8
2.03	Abbreviation	20
ARTICLE 3		
AUTHORITIES AND POWERS		
3.01	Authority	22
3.02	Delegation of Authority	23
3.03	Enforcement Powers	23
ARTICLE 4		
ADMINISTRATION		
4.01	By Irvine Ranch Water District	23
4.02	By SOCWA	24
4.03	Program Enforcement	25
4.04	Applications	25
4.05	Wastewater Discharge (WD) Permits.	25
4.06	Inspections, Monitoring, and Enforcement	25
4.07	Funding	25
4.08	Appeals	26
ARTICLE 5		
GENERAL DISCHARGE PROHIBITIONS AND LIMITATIONS		
5.01	Prohibited Discharges	26
5.02	Prohibition on Dilution	27
5.03	Prohibition on Biohazardous Waste	27
5.04	Prohibition on Toxic or Hazardous Waste	27
5.05	Prohibition on Warfare Agents	27
5.06	Limitations on Disposal of Spent Solutions and Sludges	27
5.07	Limitations on the Use of Grinders.	28
5.08	Limitations on Rainwater, Stormwater, and Street Drainage.	28
5.09	Limitations on Groundwater and Subsurface Drainage	28
5.10	Limitations on Trucked or Hauled Wastes	28
5.11	Limitations on Point of Discharge	29
5.12	Limitations on Radioactive Wastes	29
5.13	Limitations on Unpolluted Water	29

<u>Section</u>	<u>Page</u>
5.14 Mass Emission Limit Determination	29
5.15 Wastewater Strengths and Characteristics.	30
5.16 Specific Local Limits	31
5.17 State Requirements	31
5.18 Federal Requirements	32

**ARTICLE 6
WASTEWATER DISCHARGE PERMITS**

6.01 Written Authorization	32
6.02 Types of Wastewater Discharge Permits	32
6.03 Transfer Prohibition	33
6.04 Change of Ownership.	33
6.05 Excess Capacity Regulatory Fee	33
6.06 Out of Service Area Wastewater Discharge Permits	33
6.07 Required Information	33
6.08 Confidential Information	34
6.09 Class I - Wastewater Discharge (WD) Permit.	34
6.10 Class II - Wastewater Discharge (WD) Permit	34
6.11 Class III - Wastewater Discharge (WD) Permit	34
6.12 Class IV - Special Wastewater Discharge (SWD) Permit	35
6.13 Non-Industrial Wastewater Discharge (NIWD) Form	35
6.14 Application for Wastewater Discharge Permit.	35
6.15 Application for Special Wastewater Discharge Permit.	36
6.16 Application for Non-Industrial Wastewater Discharge (NIWD) Form	37
6.17 Wastewater Discharge Permit Terms, Conditions, and Limitations.	38
6.18 Wastewater Discharge Permit Duration	39
6.19 Wastewater Discharge Permit Renewal	39
6.20 IRWD's Right of Revision	40

**ARTICLE 7
PRETREATMENT EQUIPMENT REQUIREMENTS**

7.01 Pretreatment.	40
7.02 Spill Containment	40
7.03 Monitoring and Metering Equipment.	41
7.04 Drawing Submittals	41
7.05 Waste Minimization, Recycling, and Treatment	42

**ARTICLE 8
INSPECTION, MONITORING, SAMPLING,
NOTIFICATION, AND REPORTING REQUIREMENTS**

8.01 Inspection and Monitoring	42
8.02 Self-Monitoring and Reporting	43
8.03 Report of Spill, Slug Discharge, Batch Dumping, or Upset	46
8.04 Reporting of By-pass.	46
8.05 Baseline Monitoring Reports (40 CFR 403.12(b)).	47
8.06 Report on Progress in Meeting Compliance Schedules (40CFR 403.12(c)).	48
8.07 Report on Compliance with Categorical Pretreatment Standards Deadline (40 CFR 403.12(d))	49
8.08 Periodic Compliance Report	49
8.09 Right of Entry.	50
8.10 Analytical Requirements	50

<u>Section</u>	<u>Page</u>
8.11 Sample Collection	50
8.12 Timing	51
8.13 Notification of Changed Discharge	51
8.14 Notification of the Discharge of Hazardous Waste (40 CFR 403.12 (P)(1))	51

**ARTICLE 9
ENFORCEMENT**

9.01 Enforcement Scope	52
9.02 Notice of Noncompliance (NON)	53
9.03 Notice of Violation (NOV)	53
9.04 Administrative Orders (AO)	53
9.05 Wastewater Discharge Permit Suspension or Revocation	54
9.06 Termination of Service	56
9.07 Emergency Suspension	56
9.08 Injunction	56
9.09 Civil Fines and Penalties	56
9.10 Criminal Penalties	59
9.11 Public Nuisance	59
9.12 Appeals to the General Manager	60
9.13 Appeals to the Board	61
9.14 Judicial Review	62
9.15 Payment and Collection of Fees and Charges	63
9.16 Recovery of Enforcement Costs	63
9.17 Financial Security Conditions	63
9.18 Report of Analysis	64
9.19 Damage to Facilities or Interruption of Normal Operation	65
9.20 Industrial Waste Pass Through	65
9.21 Batch Dumps	65
9.22 Publication of Users in Significant Noncompliance (SNC)	65

**ARTICLE 10
FEES AND CHARGES**

10.01 Application Fee	66
10.02 Annual Wastewater Discharge Permit Fees	66
10.03 Inspection, Monitoring and Sampling Charges	66
10.04 Delinquency Fees	66
10.05 Additional Fees and Charges	66
10.06 Recording of Fees and Charges	66

**ARTICLE 11
SEVERABILITY**

11.01 Severability.	67
-----------------------------	----

**ARTICLE 12
REPEAL**

12.01 Repeal.	67
-----------------------	----

**ARTICLE 13
EFFECTIVE DATE**

13.01 Effective Date.	67
-------------------------------	----

THE BOARD OF DIRECTORS OF THE IRVINE RANCH WATER DISTRICT HEREBY ORDAINS AS FOLLOWS:

**ARTICLE 1
GENERAL PROVISIONS**

1.01 INTRODUCTION

- A. The Irvine Ranch Water District ("IRWD") was organized in 1961 under the California Water District Law (Section 34000 of the Water Code of the State of California). IRWD provides wastewater collection and treatment services to residential and commercial establishments in the City of Lake Forest area, which wastewater is treated at IRWD's Los Alisos Wastewater Reclamation Plant.
- B. The South Orange County Wastewater Authority (SOCWA) is a joint powers authority that owns and operates joint sewerage facilities in south Orange County, including effluent transmission main pipelines and ocean outfalls. SOCWA is the holder of the NPDES permits regulating the pretreatment and waste discharge requirements for the sewerage facilities. IRWD discharges wastewater from the Los Alisos Wastewater Reclamation Plant to SOCWA's Aliso Creek Effluent Transmission Main pipeline, and ultimately to SOCWA's Aliso Creek Ocean Outfall.
- C. SOCWA, IRWD, and Santa Margarita Water District are parties to a *Multijurisdictional Agreement Regarding Pretreatment Program Implementation and Enforcement* effective May 20, 2003 (Multijurisdictional Agreement), that provides for joint administration and enforcement of an industrial pretreatment program designed to ensure compliance with NPDES and other regulatory requirements in connection with IRWD's use of SOCWA's facilities. This ordinance is intended to fulfill IRWD's duties under the Multijurisdictional Agreement to adopt a pretreatment ordinance and enforcement response plan consistent with SOCWA's pretreatment program.
- D. This ordinance may be referred to as the "Pretreatment Ordinance."

1.02 OBJECTIVES

- A. The objectives of this ordinance are to:
 - 1. Ensure compliance with various regulatory agencies and the National Pollutant Discharge Elimination System (NPDES) requirements.
 - 2. Prevent the introduction of pollutants that may cause interference of sewerage facility operations.
 - 3. Identify the goals, objectives and procedures for complying with federal pretreatment standards.
 - 4. Prevent biosolids contamination.

5. Promote the opportunity to recycle and reclaim wastewaters or biosolids from sewerage facilities.
6. Encourage waste minimization and material substitution by users.
7. Protect sewerage facility employees and the general public who may be affected by wastewater, biosolids and chemical hazards.
8. Encourage the reuse, recycling and reduction of water, wastewater or solids that are discharged to sewerage facilities.
9. Minimize the discharge of volatile organic compounds that could individually or collectively contribute to a decrease in the quality of air emission from sewerage facilities.
10. Establish an effective monitoring program for the control of user discharges to sewerage facilities.
11. Establish an enforcement response plan (ERP) consistent with SOCWA's pretreatment program.
12. Equitably distribute costs among users.
13. Prevent the introduction of pollutants into sewerage facilities that may pass through a sewerage facility, inadequately treated, into the receiving waters, or otherwise be incompatible with sewerage facilities.
14. Incorporate the necessary laws and regulations in order to implement and enforce federal, State of California (State), IRWD and SOCWA standards.
15. Seek to identify users that discharge or have the potential to discharge toxic pollutants, non-compatible or excessive amounts of compatible wastes to sewerage facilities.

1.03 **PURPOSE**

A. The purpose of this ordinance is to:

1. Provide for the maximum public benefit from the use of IRWD sewerage facilities. This is accomplished by regulating the use of sewerage facilities and wastewater discharges by providing equitable distribution of costs in compliance with applicable state and federal regulations and by providing procedures that will allow IRWD to comply with requirements placed upon it by other regulatory agencies. Any revenues derived from the application of this ordinance may be used to recover the cost of providing services by IRWD which includes but are not limited to administration, monitoring, and enforcement.
2. Comply with federal and state regulations which allow IRWD to meet applicable standards for the final effluent and ocean outfall quality. This ordinance establishes quality and quantity limitations on all wastewater discharges whether or not the discharges adversely affect IRWD's sewerage facilities, processes,

ocean outfall effluent quality, or inhibit IRWD's ability to meet its specific discharge limitations. It is the intent of this ordinance to improve the quality of wastewater being received for treatment and to encourage water conservation by all users connected to a sewerage facility. It is IRWD's intent to discourage the increase in quantity (mass emission) of waste constituents being discharged. This ordinance also imposes pretreatment requirements on the degree of waste authorized to be discharged to IRWD's sewerage facilities; provides for the issuance of wastewater discharge permits or other controlling mechanism to impose additional case-by-case requirements, as appropriate, and establishes fees and other penalties for noncompliance and/or violation of this ordinance.

1.04 POLICY

A. The policy of this ordinance is to be:

1. Interpreted in accordance with the definitions set forth in Article 2. The provisions of this ordinance shall apply to the discharge of all wastes carried to IRWD sewerage facilities tributary to SOCWA facilities and should be liberally construed so as to effectuate the environmental purposes, objectives, and other provisions set forth herein.
2. Committed to wastewater reclamation and reuse in order to provide an alternate source of water supply. The adoption of programs for reclamation through secondary and tertiary wastewater treatment processes may necessitate more stringent quality requirements on wastewater discharges. In the event that more stringent quality requirements are necessary, this ordinance may be amended to reflect those changes.
3. Committed to the beneficial use of biosolids. The implementation of programs to land apply or provide for the marketing and distribution of biosolids may necessitate more stringent quality requirements on wastewater discharges. In the event that more stringent quality requirements are necessary, this ordinance may be amended to reflect these changes.
4. Committed to compliance with all applicable state and federal laws including the Clean Water Act in 33 United States Code 1251 et seq. and the general pretreatment regulations described in 40 CFR 403.

1.05 APPLICABILITY

This ordinance applies to all users that use any IRWD sewerage facilities that are tributary to SOCWA facilities.

1.06 AVAILABILITY OF SEWERAGE FACILITIES

If capacity in a sewerage facility as a whole is not available, IRWD may restrict discharge of existing users until sufficient capacity can be made available. IRWD may refuse immediate service to new users where their proposed quality or quantity of wastewater is unacceptable to the available sewerage facilities.

1.07 NOTICE TO EMPLOYEES

- A. IRWD shall provide this ordinance to each user that has received a wastewater discharge permit, upon request.
- B. Users who are issued a wastewater discharge permit shall make copies of this ordinance available to their employees at all times.
- C. All industrial dischargers shall permanently post a notice in prominent places advising employees to call IRWD in the event of an uncontrolled spill or discharge as soon as possible and to submit a report as indicated in section 8.03 or 8.04 of this ordinance. The notice shall provide for necessary instruction and information, including but not limited to:
 - 1. IRWD phone numbers.
 - 2. SOCWA phone numbers.
 - 3. Recording the time of the incident.
 - 4. Name and location of user.
 - 5. Type, concentration and volume of the discharge.
 - 6. Corrective action taken.
 - 7. Name of person reporting the incident.

**ARTICLE 2
DEFINITIONS AND ABBREVIATIONS**

2.01 DEFINITIONS CONTAINED IN PUBLICATION

- A. Unless otherwise defined herein, terms related to water quality shall be defined in the same manner as in the latest edition of Standard Methods for the Examination of Water and Wastewater, published jointly by the American Public Health Association (APHA), The American Water Works Association (AWWA), and the Water Environment Federation (WEF).
- B. The testing procedure for waste constituents and characteristics shall be as described in 40 CFR 136.

2.02 DEFINITION OF TERMS

- A. Words used in this ordinance in the singular may include the plural and the plural singular. Use of masculine shall mean feminine and the use of feminine shall mean masculine.

- B. The definitions in this ordinance are not intended to narrow the scope of definitions set forth in federal or state regulations. Unless the context specifically indicates otherwise the following terms, or pronouns used in their place, shall be interpreted as follows:
1. Act or "the Act". The Federal Water Pollution Control Act also known as the Clean Water Act as well as any amendments, guidelines, limitation or standards promulgated by the EPA pursuant to the Act, (33 USC 1251 et seq.).
 2. Approval Authority. Refers to the US Environmental Protection Agency (EPA), the California State Water Resources Control Board (SWRCB), or the local California Regional Water Quality Control Board (RWQCB).
 3. Baseline Monitoring Report (BMR). A required report for all industrial users subject to a categorical pretreatment standard. A BMR provides information that documents an industrial user's compliance status with all applicable pretreatment standards.
 4. Batch Dump. The discharge of pollutants or compatible wastes in a manner or method that is not approved or is prohibited by IRWD.
 5. Best Available Technology (BAT). A level of technology that is based on the very best (state of the art) control and treatment measures that have been developed or are capable of being developed for a particular industrial category.
 6. Best Management Practices (BMPs). A set of schedules of activities, prohibitions of practices, maintenance procedures, operating procedures and other management practices used to control a user or a group of similar users' discharge to sewerage facilities. BMPs may include, but are not limited to treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.
 7. Best Practicable Technology (BPT). A level of technology represented by the average of the best existing wastewater treatment performance levels within an industrial category.
 8. Biochemical Oxygen Demand (BOD). The quantity of oxygen utilized in the biochemical oxidation of organic matter in wastewater using appropriate testing procedure and expressed as a concentration (e.g. mg/L).
 9. Biodegradable. A material that can be decomposed by a biological process.
 10. Biohazardous Waste. Any material that is likely to transmit etiologic agents that cause, or significantly contribute to the cause of, increased morbidity or mortality of human beings as set forth by the State Medical Waste Management Act.
 11. Board. The Board of Directors of the Irvine Ranch Water District.
 12. Building Sewer. The entire length of private sewage service lateral extending from the building or structure to the to a sewerage facility, and including the connection to that sewerage facility.

13. By-Pass. Any intentional diversion of waste streams around any portion of a user's pretreatment equipment.
14. Categorical Industrial User (CIU). A user subject to a federal categorical pretreatment standard or categorical standard
15. Chain of Custody. A document used to ensure the integrity of a sample, which includes a record of each person involved in the possession of a sample, securing the sample, and final disposal of the sample.
16. Chemical Oxygen Demand (COD). The quantity of oxygen required to oxidize all compounds, both organic and inorganic, in wastewater using the appropriate testing procedure and expressed as a concentration (e.g. mg/L).
17. Class I User. Any user determined by IRWD that meets the criteria of significant industrial user (SIU) as described in 40 CFR 403.
18. Class II User. Any user determined by IRWD that is not a SIU and may discharge pollutants or non-compatible wastes which may impact sewerage facilities.
19. Class III User. Any user determined by IRWD that is not a SIU and may discharge conventional pollutants or compatible wastes, which may impact sewerage facilities.
20. Class IV User. Any user determined by IRWD that may discharge or is proposing to discharge special wastewater that may contain toxic or conventional pollutants, or non-compatible or compatible wastes which may impact sewerage facilities.
21. Code of Federal Regulations (CFR). The code of the Federal Government of the United States of America, which contains all of the federal regulations including environmental regulations.
22. Company Authorized Representative (CAR). An individual designated by the user, who is responsible for signing all submittals to IRWD and who meets the criteria as described in 40 CFR 403.
23. Compatible Waste. Waste that does not contain toxic pollutants or non-compatible wastes. This may include a combination of, but is not limited to, conventional pollutants or other wastes that sewerage facilities are designed to accept and/or remove. Compatible wastes are non-compatible when discharged in quantities that have an adverse effect on sewerage facilities or violate SOCWA's NPDES Permit, or when discharged in qualities or quantities violating any National Pretreatment Standard or other discharge requirement or as determined by IRWD.
24. Composite Sample. A collection of individual samples obtained at intervals based on an increment of either flow or time. The resulting mixture, a composite sample, forms a representative sample of the wastestream discharged during the sample period.

25. Control Authority (CA). The Irvine Ranch Water District (IRWD) and/or the South Orange County Wastewater Authority (SOCWA).
26. Conventional Pollutants. Those pollutants which are designated pursuant to section 304(a)(4) of the Act which include, biochemical oxygen demand (BOD), total suspended solids (TSS), fecal coliform, pH, and oil and grease.
27. Daily Maximum. The arithmetic average of all effluent samples for a pollutant collected during a calendar day.
28. Daily Maximum Limit. The maximum allowable discharge limit of a pollutant during a calendar day. Where Daily Maximum Limits are expressed in units of mass, the daily discharge is the total mass discharged over the course of the day. Where Daily Maximum Limits are expressed in terms of a concentration, the daily discharge is the arithmetic average measurement of the pollutant concentration derived from all measurements taken that day.
29. Discharger. Any entity which discharges or causes a discharge of wastewater that is directly or indirectly discharged to sewerage facilities. May be interchangeable with indirect discharger, industrial user, permittee, person or user.
30. Discharge Requirements. The requirements of federal, state or local public agencies having jurisdiction over the effluent discharged sewerage facilities or the environment.
31. Dry Weather Nuisance Flow (nuisance flow). Any water or other discharge that is received into storm drains from urban areas. Nuisance flow is, composed primarily of runoff from lawn or landscape watering, washing of vehicles, hosing down of paved areas, storm drain infiltration, natural groundwater from sub-drain systems and a variety of other sources associated with urban activity. This nuisance flow may be high in bacteriological contamination, oil and grease, and may have high organic and inorganic mineral content. Nuisance flow does not include stormwater, unless stormwater is captured, treated, controlled (thereby becoming a non-stormwater, nuisance flow) and discharged to the sewer during dry weather. Nuisance flows may come in contact with people or the environment in undesirable ways. Nuisance flow is a component of urban runoff.
32. Disposal. A controlled release to sewerage facilities or to the environment.
33. Effluent. Usually water or wastewater discharged partially or completely treated or untreated from any part of an industrial user or treatment plant.
34. Enforcement. A series of progressively more stringent actions used to seek compliance with federal, state or local laws, regulations, limitations and this ordinance, and guided by the Enforcement Response Plan, adopted as Resolution 2009-02. Any enforcement may include monetary fees, fines or penalties.
35. Environmental Protection Agency (EPA). The U.S. Environmental Protection Agency or, where appropriate, the Regional Water Management Division

Director, the Regional Administrator, or other duly authorized official of said agency.

36. Existing Source. Any source of discharge that is not a “New Source”.
37. Fee. Any amount assessed to a discharger for the use of any portion of a sewerage facility which shall include, but not be limited to, connection fees, monthly sewer service, wastewater discharge permit, excess capacity fee, industrial wastewater treatment, laboratory testing, industrial inspection, and monitoring fees.
38. Flow Monitoring Equipment. Equipment and/or structures provided at the user's sole expense to measure, totalize, record and/or sample incoming water to the user's site or the wastewater discharged to sewerage facilities.
39. General Manager. The individual duly designated by the Board of IRWD to administer this ordinance.
40. Grab Sample. A sample collected from a wastestream without regard to the flow in the wastestream and over a period of time not to exceed fifteen (15) minutes..
41. Grease. Includes, but is not limited to fats, oils and grease (FOG), waxes and other non-volatile materials as determined by the appropriate testing procedures.
42. Groundwater. Water that is beneath the surface of the earth.
43. Hazardous Waste. Any waste that is potentially damaging to of the environment or a person's health due to toxicity, ignitability, corrosivity, chemical reactivity or other reasons.
44. Indirect Discharge or Discharge. The introduction of Pollutants into a POTW from any non-domestic source regulated under section 307(b), (c), or (d) of the Act.
45. Industrial User. Any site that discharges industrial wastewater to sewerage facilities. May be interchangeable with discharger, indirect discharger, permittee or user.
46. Industrial Wastewater. All liquid-carried wastes or wastewater of the community, excluding domestic wastewater, and may include all wastewater from any producing, manufacturing, processing, agricultural, or other operation or location.Inspector. A person authorized by the General Manager to inspect and/or monitor any industrial user's discharge or anticipated discharge to any sewerage facility.
48. Interference. A discharge that, alone or in conjunction with a discharge or discharges from other sources, inhibits or disrupts any sewerage facilities, any treatment processes or operations or any sludge processes, use or disposal and therefore, is a cause of violation of IRWD's or SOCWA's NPDES permits (including an increase in the magnitude or duration of a violation) or prevents lawful biosolids or treated effluent use or disposal.

49. Interjurisdictional Agreements (Also referred to as Interagency Agreements). An agreement between SOCWA and any individual or combination of MA's or other local sewerage agency that defines the authority and responsibility to implement the Waste Discharge Pretreatment and Source Control Program and to enforce the regulations contained in this ordinance within the individual and/or combination of MAs, or any other local sewerage agency's service area.
50. Local Limits. A set of specific discharge limits developed and enforced by IRWD and/or SOCWA in order to implement the general and specific discharge prohibitions as described in 40 CFR 403.
51. Local Sewering Agency. Any public agency or private company responsible for the collection, treatment or disposal of wastewater to sewerage facilities that are duly authorized under the laws of the State to construct and/or maintain sewerage facilities.
52. Lower Explosive Limit (LEL). The point where an explosive gas in an area of atmosphere that is at a sufficient concentration as to result in an explosion if a sufficient ignition source is present.
53. Mass Emission Rate. The weight of material discharged to sewerage facilities during a given time interval. Unless otherwise specified, the mass emission rate shall mean pounds per day of a particular constituent or combinations of constituents.
54. May. Permissive or discretionary.
55. Member Agency (MA). Any one, combination, or all of the members of SOCWA.
56. Monthly Average. The sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during the month.
57. National Pollutant Discharge Elimination System (NPDES) Permit. The document issued for the control of discharges to surface waters of the United States as detailed in Section 402 of the Act.
58. National Pretreatment Standards. Includes the following terms established pursuant to 40 CFR 403.5 and 40 CFR 403.6: "Prohibited Discharges", "General Prohibitions", "Specific Prohibitions", "Local Limits", "Categorical Standards", "Categorical Pretreatment Standards", "Pretreatment Standards" and "Standards". These terms apply to any pollutant discharge regulations that are promulgated by the EPA in accordance with Section 307 (b) and (c) of the Act that limits and/or prohibits the wastewater discharged by users into a sewerage facility.
59. New Source. Those sources that are new as defined by 40 CFR 403.3(m).
60. Non-Compatible Waste. Waste that contains toxic or non-compatible pollutants that may pass-through or cause interference if discharged to sewerage facilities.

61. Non-Stormwater Discharge. Discharges that do not immediately originate from precipitation events unless precipitation is captured and discharged after a rain event. Including but not limited to: discharges of process water, air conditioner condensate, non-contact cooling water, vehicle wash water, sanitary wastes, concrete washout water, paint wash water, irrigation water, or pipe testing water.
62. Non-industrial Wastewater Discharge (NIWD) Form. A form issued users that are considered to have wastewater of no concern discharging to sewerage facilities. This form may contain BMPs.
63. Normal Working Day. Any period of time during which production or operation is taking place or any period which discharge to sewerage facilities is occurring..
64. North America Industry Classification System (NAICS). An industry classification system that groups establishments into industries based on the activities which they are primarily engaged.
65. Nuisance. Anything which may be injurious to health or is indecent or offensive to the senses or an obstruction to the free use of property so as to interfere with the comfort or enjoyment of life or property or which affects at the same time an entire community or neighborhood or any considerable number of persons, although the extent of the annoyance or damage inflicted upon individuals may be unequal.
66. Pass Through. A discharge from a user which exits sewerage facilities into waters of the United States in quantities or concentrations which, alone or in conjunction with any discharge from other sources, is a cause of a violation of any requirement of IRWD's or SOCWA's NPDES Permits, including an increase in the magnitude or duration of a violation.Permittee. A discharger who has received a permit to discharge wastewater into IRWD/IRWD's sewerage facilities subject to the requirements and conditions established by IRWD. May be interchangeable with discharger, indirect discharger, industrial user, person or user.
68. Person. Any individual, partnership, copartnership, firm, company, corporation, association, joint stock company, trust, estate, tenant, lessee, renter, governmental entity, or any other legal entity; or their legal representatives, agents or assigns. This definition includes all federal, state and local government entities. May be interchangeable with discharger, indirect discharger, industrial user, permittee or user.
69. Pesticides. Those compounds classified as such under Federal or State law or regulations including, but not limited to, DDT (dichlorodiphenyltrichloroethane, both isomers), DDE (dichlorodiphenylethylene), DDD (dichlorodiphenyldichloroethane), Aldrin, Benzene Hexachloride (alpha, beta and gamma isomers), Chlordane, Endrin, Endrin aldehyde, TCDD (2,3,7,8-tetrachlorodibenzo-p-dioxin), Toxaphene, Alpha-endosulfan, Beta-endosulfan, Endosulfan sulfate, Heptachlor, Heptachlor epoxide, Dieldrin Demeton, Guthion, Malathion, Methoxychlor, Merex and Parathion.

70. pH. A measure of the acidity or alkalinity of a solution, expressed in standard units.
71. Pollutant. Any substance, constituent, compound or characteristic of wastewaters on which a discharge limitation may be imposed either by IRWD, SOCWA, or the regulatory agencies empowered to regulate IRWD and SOCWA.
72. Polychlorinated Biphenyls (PCBs). Those compounds classified as such under Federal and State law or regulations including, but not limited to Aroclors 1016, 1221, 1228, 1232, 1242, 1248, 1254, 1260 and 1262.
73. Pretreatment. The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of introducing such pollutants into sewerage facilities. This reduction, elimination or alteration of pollutants can be obtained by physical, chemical, or biological process, by process changes or other means except as described by 40 CFR 403.
74. Pretreatment Equipment. Any equipment, structures or devices used for the treatment or flow limitation of industrial wastewater prior to discharge to sewerage facilities.
75. Pretreatment Requirements. Any substantive or procedural requirement related to pretreatment imposed on a user, other than a national pretreatment standard.
76. Prohibited Discharges. Any prohibitions against the discharge of certain substances; these prohibitions appear in Article 5.
77. Public Agency. The State and any city, county, district, agency, other local authority or public body of or within this state.
78. Rainwater. Water resulting from precipitation which directly falls upon any surface.
Regulatory Agencies. Those Agencies having jurisdiction over the operation of IRWD, including, but not limited to, the following:
 - a. United States Environmental Protection Agency (EPA).
 - b. State Water Resources Control Board (SWRCB).
 - c. Regional Water Quality Control Board (RWQCB).
 - d. South Coast Air Quality Management District (SCAQMD).
 - e. California Environmental Protection Agency (Cal-EPA).
80. Representative Sample Point. A location set forth in the user's wastewater discharge permit or other control mechanism from which wastewater can be collected that is as nearly identical in content and consistency as possible to that of the entire flow of wastewater being sampled. For categorical users, this point shall be at the end of each regulated process, and for all other users shall be determined on a case-by-case basis.

81. Resource Conservation and Recovery Act (RCRA). The RCRA Act of 1976 (42 U.S.A. 6901, et seq.) to implement the conservation and recovery of used or spent resources and as amended.
82. Routine Sampling. Any sampling conducted by IRWD to verify compliance of a user's discharge to sewerage facilities. Sampling may consist of either grab or composite samples or a combination of both.
83. Sampling Equipment. Equipment or structure provided at the user's sole expense for IRWD or the user to measure and record wastewater constituents, collection of samples or provide access to plug or terminate the discharge.
84. Scum. Any layer of matter or combination of air and matter that forms on or rises to the surface of a liquid or body of water.
85. Sewage. Wastewater.
86. Sewerage Facilities. Any and all systems used for collecting, conveying, pumping, reclamation, recycling, reuse, storage, transportation, treatment or disposal of sewage, industrial waste of a liquid nature, wastewater, sludge or biosolids that is owned and/or operated by IRWD, SOCWA or other public agency which is tributary to systems operated by IRWD or SOCWA. This definition includes, but is not limited to, publicly owned treatment works (POTW's) as defined by Section 212 of the Act (33 U.S.C. Section 1292), public sewers, trunk lines, sewer mains, wet wells, treatments plants and ocean outfalls which are owned by IRWD or SOCWA.
87. Shall. Mandatory.
88. Significant Industrial User (SIU). A user as defined by 40 CFR 403, except as provided in paragraphs c and d of this definition, which includes the following:
 - a. An industrial users subject to categorical pretreatment standards; or
 - b. An industrial user that: discharges an average of twenty-five (25,000) gallons per day or more of process wastewater to IRWD or SOCWA (excluding sanitary, noncontact cooling water, and boiler blowdown wastewater); contributes a process wastestream which makes up five percent (5%) or more of the average dry weather hydraulic or organic capacity of IRWD's or SOCWA's sewerage facilities; or is designated as such by IRWD on the basis that the industrial user has a reasonable potential for adversely affecting IRWD's or SOCWA's operation or for violating any pretreatment standard or requirement.
 - c. IRWD may determine that an industrial user subject to categorical pretreatment standards is a Non-Significant Categorical Industrial User (NSCIU) rather than a Significant Industrial User on a finding that the industrial user never discharges more than 100 gallons per day (gpd) of total categorical wastewater (excluding sanitary, noncontact cooling and boiler blowdown wastewater, unless specifically included in the Pretreatment Standard) and the following conditions are met:

- i. The industrial user, prior to IRWD's finding, has consistently complied with all applicable categorical pretreatment standards and requirements;
 - ii. The industrial user annually submits the certification statement required in 40 CFR 403.12(q) together with any additional information necessary to support the certification statement; and
 - iii. The industrial user never discharges any untreated concentrated wastewater.
- d. Upon a finding that an industrial user meeting the criteria in paragraph b above of this definition has no reasonable potential for adversely affecting IRWD's operation or for violating any pretreatment standard or requirement, IRWD may at any time, on its own initiative or in response to a petition received from an industrial user, and in accordance with 40 CFR 403.8(f)(6), determine that such industrial user should not be considered a significant industrial user. Significant Non-Compliance. A violation by a SIU (or any IU which violates paragraphs c, d or h of this definition) as described in 40 CFR 403.8(f)(2)(viii)(A-H) which meets one or more of the following criteria:
- a. Chronic violations of wastewater discharge limits, defined here as those in which sixty-six percent (66%) or more of all of the measurements taken for the same pollutant parameter during a six (6) month period exceed (by any magnitude) a numeric pretreatment standard or requirement, including instantaneous limits, as described in 40 CFR 403.3(l);
 - b. Technical Review Criteria (TRC) violations, defined here as those in which thirty-three percent (33%) or more of all of the measurements taken for the same pollutant parameter during a six (6) month period equals or exceeds the product of the numeric pretreatment standards or requirement including instantaneous limits, as described in 40 CFR 403.3(l) multiplied by the applicable TRC (TRC = 1.4 for BOD, TSS, fats, oil and grease, and 1.2 for all other pollutants except pH);
 - c. Any other violation of a pretreatment standard or requirement as defined in 40 CFR 403.3(l) (daily maximum, long-term average, instantaneous limit, or narrative standard) that IRWD determines has caused, alone or in combination with other discharges, interference or pass through, including endangering the health of IRWD or SOCWA personnel or the general public;
 - d. Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in IRWD's exercise of its emergency authority under 40 CFR 403.8(f)(1)(vi)(B) to halt or prevent such a discharge;
 - e. Failure to meet, within ninety (90) days after the scheduled date, a compliance schedule milestone contained in a wastewater discharge

- permit, other control mechanism or enforcement order for starting construction, completing construction, or attaining final compliance;
- f. Failure to provide within forty-five (45) days after the due date, required reports, including, but not limited to baseline monitoring reports, 90-day compliance reports, periodic self-monitoring reports and reports on compliance with compliance schedules;
 - g. Failure to accurately report noncompliance;
 - h. Any other violation or group of violations, which may include a violation of Best Management Practices, which IRWD determines will adversely affect the operation or implementation of the local pretreatment program.
90. Sludge. Any solid, semi-solid or liquid decant, subnate, or supernate from an industrial manufacturing process, utility service or pretreatment equipment.
91. Slug Discharge. Any discharge of a non-routine, episodic nature, that may exceed the standards and prohibitions contained in Article 5 of this ordinance and significantly exceeds the usual industrial flow or pollutants loading, either mass or concentration including but not limited to an accidental spill or a non-customary batch discharge, which has a reasonable potential to cause interference or pass through, or in any other way violate the regulations, local limits or permit conditions associated with sewerage facilities.
92. Solvent. Any substance that is used to dissolve another substance in it.
93. Spent Solutions. Any concentrated industrial wastewater.
94. Spill Containment. Any protection equipment provided and installed at the user's sole expense to prohibit the discharge of non-compatible wastes to sewerage facilities.
95. Standard Methods. Procedures described in the current edition of Standard Methods for the Examination of Water and Wastewater, as published jointly by the American Public Health Association, the American Water Works Association and the Water Environment Federation.
96. Stormwater. Any flow occurring during or immediately following any form of natural precipitation, which runs off, or travels over the ground surface to a drainage area or channel or drains uncontrolled to a municipal storm drain system tributary to a river, stream, lake or creek and ultimately to the Pacific Ocean.
97. Street Drainage. Water resulting from surface runoff generated by rainwater, stormwater or other sources.
98. Subsurface Drainage. A method of draining that is situated under the ground (e.g., leachate control system).

99. Surface Runoff. Runoff other than that which is caused by rainfall, stormwater, or street drainage (e.g., car wash runoff, washdown runoff) originating from a user.
100. Total Organic Carbon (TOC). The measure of total organic carbon in domestic or other wastewater as determined by the appropriate testing procedure.
101. Total Suspended Solids. Any insoluble material contained as a component of wastewater and capable of separation from the liquid portion by laboratory filtration as determined by the appropriate testing procedures and expressed in terms of milligrams per liter (mg/L).
102. Toxic Pollutant. Any pollutant or combination of pollutants listed as toxic by the EPA under the provisions of Section 307(a) of the Act or other acts or that can harm human health, aquatic life or the biological treatment processes.
103. Unpolluted Water. Water to which no constituent has been added either intentionally or accidentally.
104. Upset. Any upset that meets the criteria as described in 40 CFR 403.
105. User. Any person or entity which discharges or causes a discharge of wastewater to a sewerage facility, as defined by EPA regulations. May be interchangeable with discharger, indirect discharger, industrial user, permittee or person.
106. Volatile. Natural (plant or animal origin) or synthetic substances that is capable of being evaporated or changed to vapor at relatively low temperatures.
107. Waste. Sewage and any other waste substances, whether liquid, solid, gaseous or radioactive.
108. Waste Manifest. A receipt which is retained by the generator of hazardous wastes as required by the State or the United States Government pursuant to RCRA or the California Hazardous Materials Act or that receipt which is retained by the generator for recyclable wastes or liquid non-hazardous wastes as required by IRWD.
109. Wastewater. Liquid and water-carried industrial wastes and sewage from residential dwellings, commercial buildings, industrial and manufacturing, and institutions, whether treated or untreated, which are discharged or permitted to enter sewerage facilities.
110. Wastewater Constituents and Characteristics. The individual chemical, physical, bacteriological, radiological, volume, flow rate and such other parameters that serve to define, classify or measure the quality and quantity of wastewater.
111. Wastewater Discharge (WD) Permit. The form of authorization from IRWD issued to an industrial user for the discharge of wastewater. This wastewater discharge permit sets forth the limits and conditions under which the industrial user will be allowed to discharge wastewater into sewerage facilities.

2.03 ABBREVIATION

A. The following abbreviations shall have the designated meanings:

1. "BAT" Best Available Technology
2. "BMP" Best Management Practice
3. "BMR" Baseline Monitoring Report
4. "BOD" Biochemical Oxygen Demand
5. "BPT" Best Practicable Technology
6. "CA" Control Authority
7. "CAR" Company Authorized Representative
8. "CFR" Code of Federal Regulations
9. "CIU" Categorical Industrial User
10. "COD" Chemical Oxygen Demand
11. "CWF" Combined Wastestream Formula
12. "DO" Dissolved Oxygen
13. "EPA" Environmental Protection Agency
14. "ERP" Enforcement Response Plan
15. "FOG" Fats, Oils and Grease

16. "gpd" Gallons per Day
17. "gpm" Gallons per Minute
18. "IU" Industrial User
19. "IRWD" Irvine Ranch Water District
20. "lb/day" Pounds Per Day
21. "JPA" Joint Powers Authority
22. "LEL" Lower Explosive Limit
23. "MA" Member Agency

24.	"MGD"	Million Gallons Per Day
25.	"MSDS"	Material Safety Data Sheet
26.	"NAICS"	North America Industry Classification System
27.	"NPDES"	National Pollutant Discharge Elimination System
28.	"NSCIU"	Non-Significant Categorical Industrial User
29.	"O&G"	Oil and Grease
30.	"PCBs"	Polychlorinated Biphenyls
31.	"POTW"	Publicly Owned Treatment Works
32.	"PSES"	Pretreatment Standards for Existing Sources
33.	"PSNS"	Pretreatment Standards for New Sources
34.	"RCRA"	Resource Conservation and Recovery Act
35.	"RWQCB"	Regional Water Quality Control Board
36.	"SOCWA"	South Orange County Wastewater Authority
37.	"SIU"	Significant Industrial User
38.	"SNC"	Significant Non-Compliance
39.	"SWRCB"	State Water Resources Control Board
40.	"TDS"	Total Dissolved Solids
41.	"TOC"	Total Organic Carbon
42.	"TOMP"	Toxic Organic Management Plan
43.	"TRC"	Technical Review Criteria
44.	"TSS"	Total Suspended Solids
45.	"TTO"	Total Toxic Organics
46.	"U.S.C."	United States Code
47.	"mg/L"	Milligrams per Liter (0.001)
48.	"ug/L"	Microgram per Liter (0.000001)
49.	"ng/L"	Nanograms per Liter (0.000000001)

50. "pg/L" Picograms per Liter (0.000000000001)

**ARTICLE 3
AUTHORITIES AND POWERS**

3.01 AUTHORITY

- A. IRWD is regulated by Agencies of the United States Federal Government and the State under provisions of federal and state law. Federal law requires SOCWA and IRWD and the state grants IRWD the authority to regulate and/or prohibit the discharge of any waste, directly or indirectly, to SOCWA's or IRWD's sewerage facilities by adoption of ordinances, resolutions, issuance of wastewater discharge permits or other control mechanisms. That authority includes, but is not limited to, the right to establish local limits, conditions, prohibitions, flow rates; to prohibit flows discharged to IRWD's sewerage facilities; and to enforce federal, state and local requirements. This may require the implementation of compliance schedules for the installation of flow monitoring equipment by users and for IRWD to take all actions necessary to enforce its authority, whether within or outside IRWD's service area, including those users that are tributary to IRWD or within areas for which IRWD has contracted to provide sewerage facility services.
- B. IRWD has the authority under California Health and Safety Codes 5471 and 5474 to prescribe, revise, and collect all regulatory fees and to charge for services and sewerage facilities furnished by IRWD and/or SOCWA either within or without its service area.
- C. Administration and enforcement of the pretreatment program may be carried out on a daily basis by any individual and/or combination of IRWD personnel as granted by an interjurisdictional agreement under the oversight of SOCWA. However, SOCWA retains the authority to assume, at any time, administrative and enforcement powers of the pretreatment program requirements within IRWD jurisdiction.
- D. IRWD shall have the authority to enforce compliance with 40 CFR 403, its NPDES permit and the provisions of this ordinance by, but not limited to, the following:
 - 1. Issuing WD permits.
 - 2. Requiring the installation of pretreatment equipment.
 - 3. Requiring the installation of monitoring and/or sampling equipment and/or structures.
 - 4. Requiring self-monitoring and reporting of the user's discharge.
 - 5. Requiring the implementation of spill containment plans.

3.02 DELEGATION OF AUTHORITY

Whenever any authority or power is granted to or a duty imposed upon the General Manager, that authority or power may be exercised or that duty may be performed by a person authorized by the General Manager.

3.03 ENFORCEMENT POWERS

A. Enforcement action against a user for being in non-compliance with any provision of this ordinance may include, but is not limited to, the following:

1. Issuing a Warning Notice of Non-compliance letter.
2. Issuing a notice of non-compliance (NON) form.
3. Issuing a notice of violation (NOV) form.
4. Issuing an administrative order (AO) which may also include, but is not limited to, the following types of orders:
 - a. Probation Order (PO)
 - b. Show Cause Order (SCO)
 - c. Cease and Desist Order (CDO)
5. Petitioning the courts for injunction or civil penalties.
6. Signing criminal complaints.
7. Suspension or revocation of an issued wastewater discharge permit or other control mechanism.
8. Termination of services.
9. Bringing administrative complaints.

B. The initiation of an enforcement action shall not be a bar against, or a prerequisite for, taking any other enforcement action against the user.

**ARTICLE 4
ADMINISTRATION**

4.01 BY IRVINE RANCH WATER DISTRICT

A. IRWD shall implement pretreatment and source control programs in accordance with federal, state, and SOCWA regulations, the provisions of this ordinance, and any interjurisdictional agreements.

- B. If IRWD desires to perform its own pretreatment and source control program, it shall do so pursuant to the interjurisdictional agreement with SOCWA, under the oversight of SOCWA.
- C. IRWD, when operating its own pretreatment and source control program, shall keep SOCWA apprised of all activities on a regular and consistent basis. This may be accomplished by, but not limited to, correspondence, meetings and submittal of periodic reports.
- D. IRWD shall have the authority to use fees and charges provided for within this ordinance when a user is in non-compliance.
- E. IRWD shall provide SOCWA any and all information and submittals by users for review and central filing.
- F. IRWD, which operates its own sewerage facilities, shall coordinate with SOCWA to establish technically-based local limits. These limits shall be established in accordance with section 4.02 H. of this ordinance. These limits are to ensure that any user's effluent that is discharged to sewerage facilities does not cause any of the following:
 - 1. Upset, pass through or interference of the biological treatment process.
 - 2. Upset, pass through or interference of the sludge digestion process.
 - 3. Reclaimed or recycled water or generated biosolids to be unable to meet regulatory standards for beneficial reuse or unlimited distribution as defined by regulatory agencies.
 - 4. Violation of any IRWD or SOCWA NPDES permit limitations.
 - 5. Pass-through or interference causing IRWD or SOCWA to violate any discharge limits of the SOCWA Ocean Outfalls.

4.02 BY SOCWA

- A. SOCWA has the authority to implement pretreatment and source control programs in accordance with federal and state regulations.
- B. SOCWA has the authority to approve all forms used in the pretreatment and source control program.
- C. SOCWA has the authority to, at any time, assume administration and enforcement of this ordinance within the service area of IRWD.
- D. SOCWA has the authority to locate and terminate any non-compliant discharge that is not discontinued, upon notification that a non-compliant discharge is occurring.
- E. SOCWA has the authority to review all applications, wastewater discharge permits, other control mechanisms and any enforcement actions that have been taken.
- F. SOCWA has the authority to review all ordinances pertaining to pretreatment and source control programs before adoption or implementation by IRWD.

- G. SOCWA has the authority to audit IRWD when performing its own pretreatment and source control program.
- H. SOCWA shall oversee the establishment of technically based local limits for IRWD. A review of the local limits may be conducted every five years or in conjunction with the renewal of SOCWA's NPDES Permits.

4.03 PROGRAM ENFORCEMENT

- A. IRWD shall have first priority to enforce the regulations contained within this ordinance in accordance with, but not limited to, the following:
 - 1. SOCWA shall conduct the pretreatment and source control program for IRWD unless otherwise directed by the interjurisdictional agreement with IRWD.
 - 2. When IRWD is performing its own program it shall inform SOCWA of all program activity.
 - 3. IRWD when performing its own program shall conduct routine sampling of permitted users for constituents the industry must sample and analyze for as part of their self-monitoring program, and inform SOCWA of such activity.

4.04 APPLICATIONS

All applications for wastewater discharge permits will be reviewed by IRWD and SOCWA.

4.05 WASTEWATER DISCHARGE (WD) PERMITS

- A. All proposed WD Permits will be reviewed by IRWD and SOCWA before being issued to the user.
- B. All issued WD Permits shall be signed, identified and/or numbered by IRWD or SOCWA.

4.06 INSPECTIONS, MONITORING AND ENFORCEMENT

- A. SOCWA shall be notified by IRWD when inspecting, monitoring, or enforcement activities will or have already occurred. This may be done by, but not limited to, the following:
 - 1. Phone contact or correspondence.
 - 2. Submittal of written schedule reports or status reports.
- B. Emergency enforcement actions by IRWD shall be reported to SOCWA by phone within twenty-four (24) hours during weekdays and within seventy-two (72) hours during weekends, and by written report within five (5) days of their notice to the user.

4.07 FUNDING

- A. Subject to review by SOCWA, IRWD may establish a schedule of wastewater discharge permit application fees, annual fees, sample analysis charges, and any other fees or

charges required to recover reasonable costs of implementing a pretreatment and source control program.

- B. The industrial user shall pay IRWD for all costs incurred by IRWD for its pretreatment activity may be collected by, upon invoice.

4.08 APPEALS

- A. IRWD shall have first priority to handle appeals in accordance with the provisions of this ordinance.
 - 1. Appeals of staff action shall be directed to the General Manager.
 - 2. Appeals of the General Manager's action shall be directed to the Board.
 - 3. Actions by the Board shall be final.
- B. SOCWA shall have the authority to handle appeals where IRWD lacks sufficient jurisdiction, or fails to enforce against a user in accordance with the provision of this ordinance or the interjurisdictional agreements.

ARTICLE 5 GENERAL DISCHARGE PROHIBITIONS AND LIMITATIONS

5.01 PROHIBITED DISCHARGES

- A. These prohibitions apply to all users of sewerage facilities whether or not they are subject to categorical pretreatment standards or any other national, State or local pretreatment standards or requirement.
- B. No user shall discharge directly or indirectly a quality or quantity of wastes, solids, viscous substances, wastewater or pollutants to sewerage facilities, either alone or by interaction with other substances, which cause or will cause:
 - 1. Obstruction of flow.
 - 2. Pass through or interference.
 - 3. Inhibition of biological activity.
 - 4. The final effluent to fail a toxicity test.
 - 5. Corrosive or physical structural damage to sewerage facilities.
 - 6. Danger to life and/or safety of any person.
 - 7. Impairment of the effective maintenance or operation of any sewerage facility.
 - 8. A fire or explosion hazard based upon a closed cup flashpoint of less than 140 degrees Fahrenheit (60°C) using the test method specified in 40 CFR 261.21.

9. The presence of toxic gases, vapors, fumes, or poisonous, noxious or malodorous gas producing substances that may cause acute worker health and safety problems.
10. Any product of any sewerage facility including, but not limited to the final effluent ,biosolids, residue, sludge, or scum to be unsuitable for reclamation, reuse, or disposal.
11. Discoloration or any other condition which affects the quality of the final effluent in such a manner that discharge requirements established by regulatory agencies cannot be met.
12. Conditions which violate any statute, rule, regulation, or ordinance of any public agency or regulatory agency having jurisdiction over the discharge of wastewater through sewerage facilities.
13. The discharge of petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin, which cause interference or pass through.

5.02 PROHIBITION ON DILUTION

Except where expressly authorized to do so by an applicable standard, no user shall discharge directly or indirectly to sewerage facilities an increase in the use of water to attempt to dilute a waste being discharged, as a partial or complete substitute for treatment to achieve compliance with this ordinance, a wastewater discharge permit, other control mechanism or to establish an artificially high flow rate for mass emission rates.

5.03 PROHIBITION ON BIOHAZARDOUS WASTE

No user shall discharge directly or indirectly to sewerage facilities a biohazardous waste without rendering it non-biohazardous prior to discharge if the biohazardous waste is deemed to pose a threat to public health and safety or will result in any violation of applicable waste discharge requirements.

5.04 PROHIBITION ON TOXIC OR HAZARDOUS WASTE

No user shall discharge directly or indirectly to sewerage facilities, any substance that is defined as a toxic or hazardous waste by regulatory agencies, except those wastes which meet the requirements of 40 CFR 403.

5.05 PROHIBITION ON WARFARE AGENTS

No user shall discharge directly or indirectly to sewerage facilities any radiological, chemical, or biological warfare agent.

5.06 LIMITATIONS ON DISPOSAL OF SPENT SOLUTIONS AND SLUDGES

- A. Any spent solutions, sludges, and/or other wastes generated by the user that are a hazardous waste and not treated on site shall be hauled by a registered hazardous waste transporter. The user shall complete and maintain a hazardous waste manifest that documents the removal and transport of the waste.

- B. All hazardous waste manifests shall be retained for a minimum of three (3) years and shall be made available to IRWD upon request. IRWD may require a longer period of retention if litigation is being considered.
- C. No user shall batch dump to sewerage facilities without written approval from IRWD.

5.07 LIMITATIONS ON THE USE OF GRINDERS

Wastes from industrial or commercial grinders shall not be discharged into a sewerage facility, except wastes generated in packing or preparing food or food products on a case by case basis as approved by IRWD. Such grinders must shred the waste to a degree that all particles will be carried freely under normal flow conditions prevailing in the sewerage facilities.

5.08 LIMITATION ON RAINWATER, STORMWATER, AND STREET DRAINAGE

No user shall discharge or cause to be discharged directly or indirectly into sewerage facilities any rainwater, stormwater, or street drainage that exceeds the first one-tenth (1/10) of an inch of precipitation from any storm event.

5.09 LIMITATIONS ON GROUNDWATER AND SUBSURFACE DRAINAGE

- A. Groundwater and subsurface drainage shall not be discharged directly or indirectly to sewerage facilities except as provided herein.
- B. IRWD may approve the discharge of such water, by wastewater discharge permit or other control mechanism only, when no alternate method of disposal is reasonably available or to mitigate an environmental risk or health hazard.
- C. The discharge of such water shall require the following:
 - 1. A Class IV Special Wastewater Discharge Permit or other control mechanism issued by IRWD, and
 - 2. Documentation from the user or user's consultant that all other alternate methods of disposal have been exhausted, and
 - 3. User shall pay all applicable fees and charges and shall meet any other conditions as required by IRWD.

5.10 LIMITATIONS ON TRUCKED OR HAULED WASTES

- A. No user shall discharge trucked or hauled wastes directly or indirectly to sewerage facilities without written approval from IRWD and SOCWA. Written approval may be in the form of an individual special wastewater discharge permit or other control mechanism.
- B. No user shall transport waste from one location to another for the purpose of treating or discharging it directly or indirectly to sewerage facilities without written approval from IRWD and SOCWA. Written approval may be in the form of an individual special wastewater discharge permit or other control mechanism.

5.11 LIMITATIONS ON POINT OF DISCHARGE

No user shall discharge any wastewater directly or indirectly into a manhole or other opening in a sewerage facility other than through an approved building sewer unless approved in writing by IRWD.

5.12 LIMITATIONS ON RADIOACTIVE WASTES

- A. No user shall discharge directly or indirectly to sewerage facilities any radioactive waste except as follows:
 - 1. When the user is authorized to use radioactive materials by the California Department of Public Health or other governmental agency empowered to regulate the use of radioactive materials, and
 - 2. When the waste is discharged in strict conformity with current California Radiation Control Regulations (Cal. Code Regs. Title 17) for safe disposal, and
 - 3. When the user is in compliance with all other rules and regulations of all other applicable regulatory agencies.

5.13 LIMITATIONS ON UNPOLLUTED WATER

- A. Unpolluted water such as deionized, steam waste, distilled, single pass cooling water in excess of laboratory usage, blow-down or bleed water from cooling towers, or other evaporating coolers, or commercial swimming pool water drainage shall not be discharged directly or indirectly to sewerage facilities except as provided herein.
- B. IRWD may approve the discharge of such water when no alternate method of disposal or reuse is reasonably available or there is need to mediate an environmental risk or health hazard.
- C. The discharge of such water shall require the following:
 - 1. A Class IV Special Wastewater Discharge Permit or other control mechanism, and
 - 2. Documentation from the user or user's consultant that all other alternate methods of disposal have been exhausted, and
 - 3. User shall pay all applicable fees and charges and shall meet any other conditions as required by IRWD.

5.14 MASS EMISSION LIMIT DETERMINATION

- A. Mass emission limits for non-compatible and compatible wastes that are present or anticipated in the user's wastewater discharge may be set for each user and made an applicable part of each user's wastewater discharge permit or other control mechanism. These limits shall be based on Table I, local limits or national pretreatment standards and the user's average daily wastewater discharge for the past three (3) years, the most recent representative data, or other data acceptable by IRWD.

- B. To verify the user's operating data, the user may be required to submit an inventory of all wastewater streams and production data.
- C. IRWD may revise local limit concentration limits or mass emission limits previously established in the user's wastewater discharge permit or other control mechanism at any time, based on current and/or anticipated operating data, the ability to meet NPDES Limits, and/or changes in the requirements of regulatory agencies.
- D. The increased use of water to establish an artificially high flow rate data base for mass emission limit determinations is prohibited.

5.15 WASTEWATER STRENGTHS AND CHARACTERISTICS

- A. No user shall discharge wastewater directly or indirectly to sewerage facilities with the following strengths and characteristics:
 - 1. Having a temperature higher than 140 degrees Fahrenheit (60 degrees Centigrade) or which causes the temperature at the influent to a wastewater treatment plant to exceed 104 degrees Fahrenheit (40 degrees Centigrade).
 - 2. Containing substances that may precipitate, solidify, or become viscous at temperatures between 50 degrees Fahrenheit (10 degrees Centigrade) and 104 degrees Fahrenheit (40 degrees Centigrade).
 - 3. Containing materials which will readily settle or cause an obstruction to flow in sewerage facilities or be detrimental to the proper operation of a sewerage facility. These materials may include, but are not limited to, asphalt, concrete, dead animals, offal ashes, sand, mud, straw, industrial process shavings, metal, glass, rags, feathers, tar, plastics, wood, whole blood, bones, hair, coffee grounds, egg shells, flashings, diatomaceous earth, seafood shells, and paper products not intended for use in sewerage facilities.
 - 4. Producing a gaseous mixture that is ten percent (10%) or greater of the lower explosive limit (LEL). Prohibited materials include, but are not limited to, gasoline, kerosene, naphtha, benzene, toluene, xylene, ethers, ketones, and alcohols.
 - 5. Having a pH less than 5.0 or greater than 11.0.
 - 6. Containing recognizable portions of human or animal anatomy. Containing excessive flow, constituents or other materials, including but not limited to, biological oxygen demand, chemical oxygen demand, total organic carbon, toxic pollutants, suspended solids, grease and oil of animal or vegetable origin total dissolved solids, detergents, surface active agents, phenolic compounds or other substances that are released in a discharge at a flow rate and/or concentration which will cause problems, pass-through or interference with sewerage facilities.
 - 8. Containing PCBs in excess of 0.01 mg/L as a daily maximum.
 - 9. Containing pesticides in excess of 0.01 mg/L as a daily maximum.

10. Violation of any applicable national pretreatment standards, state standards, or other local regulations covering wastewater disposal.

5.16 SPECIFIC LOCAL LIMITS

- A. IRWD in coordination with SOCWA is authorized to establish local limits pursuant to 40 CFR 403.
- B. No user shall discharge directly or indirectly a quality or quantity of wastes or wastewater containing toxic pollutants, non-compatible or compatible wastes in excess of Table I, Specific Local Limits. All local limits for the metal pollutants are for the “total metal” amount analyzed, unless indicated otherwise.

Table I

Specific Local Limits

Pollutant	Limit (mg/L)
Arsenic	3.4
Cadmium	0.93
Chromium	4.9
Copper	7.2
Lead	4.9
Mercury	0.19
Nickel	9.5
Silver	2.8
Zinc	7.9
Cyanide	4.3
Oil and Grease	300

- C. Local limits are subject to more stringent standards as established by national pretreatment standards. Local limits are deemed to be pretreatment standards for the purposes of Section 307(d) of the Act, and are enforceable under Section 309 of the Act, potentially subjecting an IU to a penalty of \$25,000 per day for each violation.
- D. IRWD may place more stringent standards within any wastewater discharge permit or other control mechanism issued to a user at any time, based on current and/or anticipated operating conditions presented in the wastewater discharge permit application, the ability to meet NPDES permit limits, and/or changes in the requirements of regulatory agencies.
- E. IRWD may develop Best Management Practices (BMPs) for use in any wastewater discharge permit or other control mechanism to implement local limits and the requirements in this ordinance.

5.17 STATE REQUIREMENTS

Upon the adoption of any state requirements on user discharges that are more stringent than federal requirements or the limitations contained in this ordinance, that state standard shall then immediately supersede the federal standard and the limitations of this ordinance.

5.18 FEDERAL REQUIREMENTS

- A. Upon adoption of a national pretreatment standard more stringent than those contained in this ordinance, the federal standard shall immediately supersede the limitations listed in this ordinance and the affected significant industrial users shall be notified of the new standards and applicable reporting requirements.
- B. The significant industrial user shall comply with the national pretreatment standard within the time provided in the federal regulations that establish such standards even if their wastewater discharge permit has not yet been modified to incorporate the new requirement or standards.
- C. The significant industrial user shall comply with any applicable requirements under Sections 204(b) and 405 of the Act and Subtitles C and D of the RCRA.

**ARTICLE 6
WASTEWATER DISCHARGE PERMITS**

6.01 WRITTEN AUTHORIZATION

- A. Users may be required to obtain written authorization to use sewerage facilities. This written authorization may be in the form of a wastewater discharge permit or other control mechanism issued by IRWD. No vested right shall be given or be granted by issuance of a wastewater discharge permit or other control mechanism as provided for in this ordinance.
- B. When written authorization is granted, all the types of wastewater discharge permits and any other control mechanisms shall be expressly subject to all provisions of this ordinance and all other regulations, charges for use and fees established by IRWD. The requirements contained in wastewater discharge permits or other control mechanisms are subject to enforcement under this ordinance and under state and federal law.
- C. All users that have obtained written authorization shall discharge their process wastewater only as provided for by their wastewater discharge permit or other control document.
- D. Compliance with wastewater discharge permit or other control mechanism provisions does not relieve the user from complying with any other applicable federal, state or local requirement.

6.02 TYPES OF WASTEWATER DISCHARGE PERMITS

- A. The wastewater discharge permit may be in one of four (4) types and is dependent upon process, volume and pollutant characteristics of the users discharge. The four types of wastewater discharge permits are:
 - 1. Class I – Wastewater Discharge (WD) Permit.
 - 2. Class II – Wastewater Discharge (WD) Permit.

3. Class III – Wastewater Discharge (WD) Permit.
4. Class IV – Special Wastewater Discharge (SWD) Permit.

6.03 TRANSFER PROHIBITION

Wastewater discharge permits issued under this ordinance are for a specific user, for a specific operation at a specific location. Wastewater discharge permits shall not be transferred for an operation at a different location.

6.04 CHANGE OF OWNERSHIP

- A. Upon the sale or transfer of ownership of any business operating under a wastewater discharge permit issued by IRWD, the user shall notify IRWD in writing prior to the change of ownership. The successor owner shall be required to apply for a new wastewater discharge permit prior to the sale or transfer of ownership.
- B. In the event that the original owner fails to notify IRWD of the sale or transfer of ownership than said original owner may be jointly liable for any charges incurred by the new owner.
- C. This does not relieve the new owner of any liability for non-compliance with any federal, state, or local regulations or the provisions of this ordinance.

6.05 EXCESS CAPACITY REGULATORY FEE

New users or existing users that expand operations that require substantial sewerage facility capacity may be subject to an excess capacity sewerage facility regulatory fee in an amount and method to be solely determined by IRWD on a case-by-case basis.

6.06 OUT OF SERVICE AREA WASTEWATER DISCHARGE PERMITS

Wastewater discharge permits for users located outside of IRWD's service area but tributary to IRWD's sewerage facilities shall only be issued after approval by IRWD. Inspection and sampling of the user's discharge to determine compliance with discharge regulations will be made under a coordinated plan developed by SOCWA, IRWD and the local sewerage agency. The more stringent discharge regulations and effluent limitations of affected agencies shall apply to the user. The fees for use shall be determined by IRWD and set forth in an interjurisdictional agreement.

6.07 REQUIRED INFORMATION

- A. To provide for the equitable use of sewerage facilities, and as a condition of continued usage of the sewerage system, upon request by IRWD, a user shall provide all information necessary to maintain compliance with the provisions of this ordinance, including treatability studies to determine whether the wastewater would be compatible with all sewerage facilities. This information shall include, but is not limited to the following:
 1. Wastewater discharge flow rates, peak flow rates and volume over any period of time.

2. Physical, chemical or bacteriological analysis of wastewater.
3. Information on raw materials, processes and products.
4. Quantity, disposition and waste manifests of specific liquids, sludge, oil, solvent or other materials.
5. Details of any pretreatment equipment.
6. Details of systems to prevent and control the loss of material through spills and slug discharges.
7. Review of all types of water bills.

6.08 CONFIDENTIAL INFORMATION

All user information and data on file with IRWD shall be available to the public and governmental agencies without restriction, unless the user specifically requests and is able to demonstrate to the satisfaction of IRWD that the release of such information would divulge information, processes or methods which would be detrimental to the user's competitive position. The demonstration of the need for confidentiality made by the user must meet the burden necessary for withholding such information from the general public under applicable state and federal law. Any such claim must be made at the time of submittal of the information by marking "Confidential Business Information" on each page containing such information within the submittal. Information which is demonstrated to be confidential shall not be transmitted to any governmental agency without prior notification to the user. Information concerning wastewater quality and quantity shall not be recognized as confidential information and shall be available to the public without reservation.

6.09 CLASS I – WASTEWATER DISCHARGE (WD) PERMIT

No user requiring a Class I WD Permit shall discharge wastewater without obtaining a Class I WD Permit. A Class I user, as determined by IRWD, proposing to discharge directly or indirectly into a sewerage facility shall obtain a WD Permit by filing an application and paying any applicable fees before discharging.

6.10 CLASS II – WASTEWATER DISCHARGE (WD) PERMIT

No user requiring a Class II WD Permit shall discharge wastewater without obtaining a Class II WD Permit. A Class II user, as determined by IRWD, proposing to discharge directly or indirectly into a sewerage facility shall obtain a WD Permit by filing an application and paying any applicable fees before discharging.

6.11 CLASS III – WASTEWATER DISCHARGE (WD) PERMIT

No user requiring a Class III WD Permit shall discharge wastewater without obtaining a Class III WD Permit. A Class III user, as determined by IRWD, proposing to discharge directly or indirectly into a sewerage facility shall obtain a WD Permit by filing an application and paying any applicable fees before discharging.

6.12 CLASS IV – SPECIAL WASTEWATER DISCHARGE (SWD) PERMIT

- A. No user requiring a Class IV SWD Permit shall discharge wastewater without obtaining a Class IV SWD Permit. A Class IV user, as determined by IRWD, proposing to discharge directly or indirectly into a sewerage facility shall obtain a SWD Permit by filing an application and paying any applicable fees before discharging.
- B. The SWD Permit may be issued when no alternative method of disposal is reasonably available or to mitigate an environmental risk or health hazard.
- C. A user proposing to discharge diverted urban nuisance water may be issued a nuisance special wastewater discharge (NSWD) Permit only after they have completed the requirements contained in IRWD and SOCWA “Nuisance Flow Diversion Policy.”
- D. A user proposing to discharge trucked or hauled wastes may be issued a hauled special wastewater discharge (HSWD) Permit only after they have completed all requirements set forth by IRWD on a case by case basis. All trucked or hauled waste users shall comply with the terms, conditions and limitation set forth in a HSWD Permit as determined by IRWD to be necessary to protect sewerage facilities. A trucked or hauled waste user proposing to discharge waste into a IRWD or SOCWA sewerage facility may be required to obtain both a valid Orange County Health Department permit (where applicable) and a HSWD Permit prior to any discharge.

6.13 NON-INDUSTRIAL WASTEWATER DISCHARGE (NIWD) FORM

- A. At the sole discretion of IRWD, any user that is considered to have wastewater of no concern discharging to sewerage facilities may be classified as an NIWD user and issued an NIWD form.
- B. Any user that has had a Class I, II, or III WD Permit that no longer has a discharge containing noncompatible wastes to IRWD’s sewerage facilities may be classified as an NIWD user and issued an NIWD form.
- C. The main functions of the NIWD form are to assist in maintaining IRWD’s user survey data base and to track and verify by inspection any user that is considered to have wastewater of no concern discharging to sewerage facilities.

6.14 APPLICATION FOR WASTEWATER DISCHARGE PERMIT

- A. Users required to obtain a WD Permit shall complete and file with IRWD, prior to commencing discharge, if applicable, an application on a form prescribed by IRWD.
- B. Users seeking a WD Permit may be required to submit, in unit and terms appropriate for evaluation, the following information:
 - 1. Name, address of the site, NAICS numbers (if applicable), and a description of the manufacturing process or service activity.
 - 2. Name, address of any and all, (whichever is applicable) principals/owners/major share holders of company; articles of incorporation; most recent report of the Secretary of State and business license.

3. Flow, volume, time, duration and type of wastewater to be discharged.
 4. Name, address and contact information of the individual who shall serve as the CAR.
 5. Name and address of property owner, landlord and/or manager of the property.
 6. Water supplier and water account numbers. Wastewater constituents and characteristics as required or deemed necessary by IRWD, including but not limited to, those mentioned in this ordinance. These constituents and characteristics shall be determined by a laboratory of the discharger approved by IRWD.
 8. Number of employees and average hours of work per employee per day.
 9. Waste minimization, best management practices and water conservation practices.
 10. All production records, if applicable.
 11. Waste manifests, if applicable.
 12. Tons of cooling tower capacity, if applicable.
 13. List of other environmental control permits and EPA Hazardous Waste Generator number, if applicable.
 14. Application signed by CAR of the user and contains the certification statement in Section 802.E
 15. Any other information as specified.
- C. Users may be required to submit site floor, mechanical, plumbing, toxic organic management, and spill containment plans for evaluation.
- D. After evaluation of the data furnished, IRWD may issue a WD Permit, a NIWD Form or other control mechanism subject to the terms and conditions set forth in this ordinance and as otherwise determined by the General Manager to be necessary to protect sewerage facilities.
- E. The WD Permit application may be denied if the user fails to establish to IRWD's satisfaction that adequate pretreatment equipment is included within the user's plans to ensure that the discharge limits will be met or if the user has, in the past demonstrated an inability to comply with applicable discharge limits or has in the past demonstrated an inability to keep current with invoices for the items such as WD Permit fees, noncompliance fees, civil penalties, administrative civil penalties or charge for use.

6.15 APPLICATION FOR SPECIAL WASTEWATER DISCHARGE PERMIT

- A. Users required to obtain a SWD Permit shall complete and file with IRWD, prior to commencing discharge, if applicable, an application on a form prescribed by IRWD.

- B. Users seeking a SWD Permit may be required to submit, in unit and terms appropriate for evaluation, the following information:
 - 1. Name, address and a description of the wastewater to be discharged.
 - 2. Name, address and contact information of the individual who shall serve as the CAR.
 - 3. Volume, time and duration of wastewater to be discharged.
 - 4. Construction and plumbing plans, if applicable.
 - 5. Detailed analysis of the alternatives for wastewater disposal, if applicable.
 - 6. Wastewater constituents and characteristics as required or deemed necessary by IRWD, including but not limited to, those mentioned in this ordinance. These constituents and characteristics shall be determined by a laboratory selected by the user acceptable to IRWD.
 - 7. Any other data as specified.
- C. Users may be required to submit site, mechanical, plumbing, toxic organic management, and spill containment plans for evaluation if applicable.
- D. After evaluation of the information furnished, IRWD may issue a SWD Permit or other control mechanism subject to the terms and conditions set forth in this ordinance and as otherwise determined by the General Manager to be necessary to protect sewerage facilities.
- E. In the case of diverted urban nuisance water, after evaluation of the information furnished, IRWD may issue a NSWD Permit, subject to the terms and conditions set forth in this ordinance and the "Nuisance Flow Diversion Policy" as otherwise determined by the General Manager to be necessary to protect sewerage facilities.
- F. The SWD Permit application may be denied if the user fails to establish to IRWD's satisfaction that adequate pretreatment equipment is included within the user's plans to ensure that the discharge limits will be met or if the user has, in the past demonstrated an inability to comply with applicable discharge limits or has in the past demonstrated an inability to keep current with invoices for items such as SWD Permit fees, non-compliance fees, civil penalties, administrative civil penalties or charges for use .

6.16 APPLICATION FOR NON-INDUSTRIAL WASTEWATER DISCHARGE (NIWD) FORM

- A. Users meeting the criteria for a NIWD form may be asked to complete and file with IRWD an application on a form prescribed by IRWD.
- B. Information on users that meet the criteria for a NIWD form may be obtained solely by IRWD during site inspections or by other means.
- C. After evaluation of the data furnished by the user or from information collected solely by IRWD an NIWD form may be issued.

6.17 WASTEWATER DISCHARGE PERMIT TERMS, CONDITIONS, AND LIMITATIONS

- A. All wastewater discharge permits shall be expressly subject to all terms, conditions, and limitations of this ordinance, other regulatory agencies, Best Management Practices, charge for use, and fees established by IRWD. The terms, conditions, and limitations in a WD Permits are subject to enforcement by IRWD in accordance with this ordinance, and applicable state and federal regulations. Any WD Permit violation shall be a violation of this ordinance.
- B. The terms, conditions, and limitations of any issued WD Permit may be subject to modification and changes by IRWD during the life of the WD Permit based on:
 - 1. The discharger's current or anticipated operating data.
 - 2. IRWD's current or anticipated operating data.
 - 3. Changes in the requirements of regulatory agencies.
- C. Users may request a modification to the terms, conditions, and limitations of an issued WD Permit. The request shall be in writing stating the requested change, and the reasons for the change. IRWD shall review the request, make a determination and respond in writing. A request for a wastewater discharge permit modification does not relieve a user from complying with its existing WD Permit terms, conditions and limitations.
- D. Any changes to the terms, conditions or limitations in a WD Permit shall include a reasonable time schedule for compliance where allowed under applicable federal, state and local law.
- E. A WD Permit may contain any, but is not limited to, the following terms, conditions and limitations:
 - 1. Effluent limits, including mass emission rates, concentration limits or best management practices based on applicable pretreatment standards for regulated pollutants.
 - 2. Discharge limits based upon the combined wastestream formula (CWF).
 - 3. Limits on rate and time of discharge or requirements for flow regulation and equalization.
 - 4. Requirements for the user to make notification in writing prior to the physical expansion or any change to any wet processes. Notification is also required in the event of changes in production if production-based limits are being applied.
 - 5. Requirements for the user to construct and maintain, at the user's own expense, pH control, flow monitoring and/or sampling equipment and/or structures.
 - 6. Requirements for submission of technical reports, discharge reports and waste manifests.

7. Location of sampling point(s) and the requirements to self-monitor. Requirements for maintaining plant records relating to wastewater discharge and waste manifests as specified by IRWD.
9. Predetermined rates or values for wastewater strength characteristics.
10. Requirements to submit copies of water bills.
11. Other provisions which may be applicable to ensure compliance with this ordinance.
12. Other terms, conditions and limitations determined by IRWD to be necessary to protect sewerage facilities.
13. Predetermined rate or value for BOD and suspended solids.
14. Requirements for notification of bypass discharges.
15. Requirements for notification of any new introduction of wastewater constituents or any substantial change in the volume or character of wastewater constituents.
16. Requirements to meet compliance schedules.
17. Requirements for the user to control slug discharges by developing and implementing a slug discharge control plan if determined by IRWD to be necessary as described in 40 CFR 403.8(f)(1)(iii)(B)(6).
18. Requirements for the user to control toxic organic discharges by developing and implementing a toxic organics management plan if determined by IRWD to be necessary.

6.18 WASTEWATER DISCHARGE PERMIT DURATION

All wastewater discharge permits shall not exceed a duration of five (5) years. Any wastewater discharge permit may be issued for a shorter period of time at the sole discretion of IRWD.

6.19 WASTEWATER DISCHARGE PERMIT RENEWAL

- A. The user may file a new application prior to the expiration date of any existing wastewater discharge permit for renewal.
- B. Discharge after the termination date of a wastewater discharge permit is prohibited except:
 1. If the user filed a timely renewal application which is complete, and:
 2. IRWD, through no fault of the user, does not issue a new wastewater discharge permit with an effective date on or before the expiration date of the previous wastewater discharge permit.

6.20 IRWD'S RIGHT OF REVISION

- A. IRWD reserves the right to establish, by ordinance, or by wastewater discharge permit or by Best Management Practices, or by any other control mechanism, more stringent standards or requirements on users' discharge to sewerage facilities
- B. The terms, conditions and limitations contained in any WD Permit, Best Management Practices or other control mechanism may be modified by IRWD at any time. This modification shall be by written notification to the user.

**ARTICLE 7
PRETREATMENT EQUIPMENT REQUIREMENTS**

7.01 PRETREATMENT

- A. All pretreatment equipment or devices may be reviewed by IRWD. Such review shall not absolve the user of any responsibility of meeting prohibitions, limitations, requirements, standards and local limits on discharges.
- B. User shall provide wastewater treatment as necessary which may include, but is not limited to, the use of best available technology (BAT) or best practicable technology (BPT) concepts to comply with this ordinance and shall achieve compliance with all prohibitions, limitations, standards and local limits before discharging to any sewerage facility. Any equipment required to pretreat, sample, control or transport wastewater shall be provided and maintained in proper operating condition at all times at the user's sole expense.
- C. User may be required to submit waste analysis plans, contingency plans, and meet other requirements to ensure proper operation of pretreatment equipment and compliance with their wastewater discharge permit limits and this ordinance.
- D. No user shall increase the use of water or in any other manner attempt to dilute a discharge as a partial or complete substitute for treatment to achieve compliance with this ordinance, a wastewater discharge permit or other control mechanism.

7.02 SPILL CONTAINMENT

- A. Each user shall provide spill containment for protection against the discharge of prohibited materials or other wastes regulated by this ordinance. This protection shall be designed in accordance with reasonable engineering standards to secure the discharges and to prevent them from entering into a sewerage facility. This equipment shall be provided and maintained at the user's sole expense.
- B. If it can be shown that a user's spill containment equipment did not prevent a discharge which caused IRWD to violate its requirements, incur additional operational expenses, or suffer loss or damage to sewerage facilities, that user shall be responsible for any costs or expenses, including assessment by other agencies or any costs incurred by IRWD.

- C. A notice may be permanently posted on the user's bulletin board or other prominent place advising employees who to call in the event of a prohibited discharge. Employers shall ensure that all employees who may cause or suffer such a prohibited discharge to occur are advised of the emergency notification procedure.

7.03 MONITORING AND METERING EQUIPMENT

- A. The user may be required to construct and maintain in proper operating condition at the user's sole expense, flow and/or constituent monitoring and/or sampling equipment.
- B. Any sample taken from a user's sample point shall be considered to be representative of the discharge to sewerage facilities.
- C. Monitoring or metering equipment may be required to include a security enclosure that can be locked with a IRWD provided lock during any sampling and monitoring periods.
- D. Location of the monitoring or metering equipment shall be subject to approval by IRWD.
- E. IRWD shall be provided clear and uninterrupted access to monitoring or metering locations.
- F. When one or more users discharge into a sewerage facility, those users may be required to install a separate monitoring location for each user. Also in the judgment of IRWD, if there is a significant difference in wastewater constituents and characteristics produced by different operations of a single user, that user may be required to install separate monitoring locations for each operation. Separate monitoring may also be required for different processes subject to categorical pretreatment standards.
- G. Users with the potential to discharge flammable solutions may be required to install and maintain at their sole expense a combustible gas detection meter.
- H. All wastewater samples shall be representative of the user's discharge. Wastewater monitoring and flow measurement equipment shall be operated, kept clean, and maintained in good working order at all times. Failure by the user to keep its monitoring equipment in good working order shall not be grounds for the user to claim that sample results are unrepresentative of its discharge.

7.04 DRAWING SUBMITTALS

- A. Detailed plans of any proposed construction of pretreatment, spill containment, monitoring and metering equipment and operating procedures shall be submitted for review by the due date contained within a written request from IRWD. The review of the plans and procedures shall in no way relieve the user of the responsibility of modifying the equipment or procedures in the future as necessary to meet the requirements of this ordinance or any other requirement of other regulatory agencies.
- B. All drawings shall include:
 - 1. North arrow.
 - 2. Scale size.

3. User name and address.
 4. Date drawn or revised.
 5. Location of proposed pretreatment, spill containment, monitoring and metering equipment.
- C. IRWD may require drawings to scale depicting the manufacturing process (waste generating source), spill containment, pretreatment and/or monitoring or metering equipment.
- D. IRWD may require a schematic drawing of the pretreatment, spill containment, monitoring and metering equipment.
- E. IRWD may require the drawings be prepared by a California registered chemical, mechanical, or civil engineer.

7.05 WASTE MINIMIZATION, RECYCLING, AND TREATMENT

- A. User shall provide waste minimization plans to conserve water, investigate product and/or materials substitution, maintain inventory control records and implement employee education, and other steps as necessary to minimize waste produced by the due date contained within a written request from IRWD.
- B. Waste minimization, recycling and treatment shall be demonstrated wherever feasible in the following priority:
1. Source reduction which includes, but is not limited to, substitution of less hazardous materials, spill prevention and control measures, proper storage and handling of chemicals and raw materials.
 2. Recovery and reuse which includes, but is not limited to, substitution of less hazardous materials, spill prevention and control measures, proper storage and handling of chemicals and raw materials.
 3. Treatment which includes, but is not limited to, pretreatment techniques as to render hazardous wastes harmless or suitable for disposal to sewerage facilities.

ARTICLE 8 INSPECTION, MONITORING, SAMPLING, NOTIFICATION, AND REPORTING REQUIREMENTS

8.01 INSPECTION AND MONITORING

- A. IRWD may inspect and sample the wastewater generating and disposal equipment of any user's site to ascertain whether the requirements of this ordinance are being met and the user is complying with all requirements.
- B. Where a user has instituted security measures requiring proper identification and clearance before entry onto the premises, the user shall make all necessary

arrangements with its security in order that the inspectors of IRWD shall be allowed to enter the premises without delay for the purpose of performing their authorized duties.

- C. IRWD shall have the right to set up on the user's property or any other locations, as determined by IRWD, such devices as are necessary to conduct sampling or metering operations of the user's discharge to sewerage facilities.
- D. In order for IRWD to determine the wastewater characteristics of a discharge for compliance with this ordinance, wastewater discharge permit, or other control mechanism requirements, the user may be required to make available for inspection and copying all records including, but not limited to, production records, required self-monitoring and chain of custody records, any additional records of information obtained pursuant to monitoring activities undertaken by the user independent of such requirements, documents associated with Best Management Practices and waste manifests without restriction, but subject to the confidential provisions set forth in this ordinance. All records shall be maintained by users for a minimum of three (3) years. This period shall be automatically extended for the duration of any litigation concerning the user, or when the user has been notified by written request from IRWD. Such records shall be made available to IRWD upon request.
- E. Any temporary or permanent obstruction to safe and easy access to the user's site to be inspected and/or sampled shall be promptly removed by the user at the written or verbal request of IRWD and shall not be replaced. The costs of cleaning such access shall be at the sole expense of the user.
- F. Inspection and/or sampling of any user's site shall be conducted at any time, by any means, in any amount, at any location, on any limit, requirement or pollutant in a manner and frequency as determined at the sole discretion of IRWD.

8.02 SELF-MONITORING AND REPORTING

- A. Self-monitoring of wastewater pollutants, constituents and characteristics of the user needed for determining compliance with any limitations and requirements as specified in the user's wastewater discharge permit, federal regulations, or this ordinance may be required. The self-monitoring requirement, frequency, forms and reporting shall be set forth in the user's wastewater discharge permit or other control mechanism. These reports may include, but are not limited to, the following:
 - 1. Baseline monitoring reports (BMRs).
 - 2. Compliance schedule progress reports.
 - 3. 90-day compliance reports.
 - 4. Self-monitoring reports containing monitoring and analysis to demonstrate continued compliance as described in 40 CFR 403.12(g)(1-6).
 - 5. Other reports as required by IRWD, other regulatory agencies or applicable law.
- B. Failure by the user to perform any self-monitoring or reporting required by IRWD is a violation of this ordinance, and is a violation for each parameter and each day in the time

period for which monitoring was required, and is cause for IRWD to initiate all necessary tasks and analysis to the wastewater pollutants, constituents and characteristics for any limitations and requirements specified in the user's wastewater discharge permit or in this ordinance. The user shall be responsible for any and all expenses incurred by IRWD in undertaking such monitoring analysis and preparation of reports. All users required to sample and analyze their wastewater shall use the sampling methods and the sampling locations as set forth in their wastewater discharge permit. For each sample collected and analyzed, the user shall maintain a record of:

1. Date, exact place, method and time of sampling and the name of the person taking the sample.
 2. Date analysis performed.
 3. Identity and address of the person who performed the analysis.
 4. The analytical methods used.
 5. Results of the analysis.
- D. Samples taken shall be representative of conditions occurring during the reporting period. Users shall submit all monitoring data, even if user samples more frequently than required by its wastewater discharge permit. User is required to provide advance notice of any substantial change in the volume or character of pollutants in their discharge.
- E. When required, all submitted applications and user reports shall be signed by the CAR as defined in this ordinance. Each application and any required user report shall contain the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

Date: _____

Signature: _____

Print Name: _____

Title: _____

User Name: _____

User Site
Address: _____

User Mailing Address: _____

Phone: _____

Permit No: _____

- F. Self-monitoring reports shall be subject to the provisions of 18 U.S.C. Section 1001 relating to false statements and fraud and the provisions of Section 309(c)(2) of the Act governing false statements.
- G. The analysis of a user's wastewater pollutants, constituents and characteristics shall be done by a laboratory approved by IRWD.
- H. If self-monitoring indicates a violation, the user shall notify IRWD within 24 hours of becoming aware of the violation. The user shall repeat the sampling and analysis and submit the results of the repeat analysis to IRWD within 30 days after becoming aware of the violation. Resampling by a user is not required if IRWD performs the sampling at the user's site at least once a month, or if IRWD performs sampling at the user between the time when the initial sampling was conducted and the time when the user or the user or the IRWD receives the results of the sampling, or if IRWD has performed the sampling and analysis in lieu of the user. The analysis of wastewater pollutants, constituents and characteristics and the preparation of the self-monitoring report shall be done at the sole expense of the user.
- J. The user shall establish and maintain a sample point on each discharge line at a location representative of the discharge to sewerage facilities. The maintenance of any sample point equipment shall be done at the sole expense of the user. Any sampling location shall be set forth in the user's wastewater discharge permit.
- K. Any user subject to the reporting requirements of this ordinance shall retain all records of monitoring activities and results for a minimum of three (3) years and shall make them available to IRWD upon request. IRWD may require a longer period of retention if litigation is being considered or has resulted.
- L. Any user subject to self-monitoring reporting requirements may be required to submit self-monitoring reports on forms approved by IRWD.
- M. Any user determined to be a non-significant categorical industrial user (NSCIU) by SOCWA pursuant to Section 202.B.86.c. and 808.B shall annual submit the following certification statement signed by the CAR as defined in this ordinance. This certification shall accompany an alternative report required by SOCWA:

"Based on my inquiry of the person or persons directly responsible for managing compliance with categorical pretreatment standards under 40 CFR ____, I certify that, to the best of my knowledge and belief that during the period from January 1, ____ to December 31, ____:

(a) The facility described as _____ met the definition of non-significant categorical industrial user as described in Section 202.B.86.c.;

(b) The facility complied with all applicable pretreatment standards and requirements during this reporting period; and (c) the facility never discharged more than 100 gallons of total categorical wastewater on any given day during this reporting period.

Date: _____ Signature: _____

Print Name: _____

This compliance certification is based on the following information.

8.03 REPORT OF SPILL, SLUG DISCHARGE, BATCH DUMPING OR UPSET

- A. In the event the user is unable to comply with any of the wastewater discharge permit conditions due to a breakdown of equipment, accidents caused by human error, or intentional action by any party, or acts of God, or any other cause, the discharger shall notify IRWD as soon as possible of any spill, slug discharge, batch dumping or upset.
- B. Confirmation of this notification shall be made in writing within five (5) working days of the original notification unless waived by IRWD. The written notification shall contain:
 - 1. Date of the incident.
 - 2. Reason for the spill, slug discharge, batch dumping or upset.
 - 3. The steps that were taken to immediately correct the problem.
 - 4. The steps that are being taken to prevent the problem from recurring.
 - 5. Any other information IRWD deems relevant.
- C. Such notification shall not relieve the user of any expense, loss, damage, liability or fees which may be incurred as a result of damage or loss to sewerage facilities or any damage or loss to persons or property. Such notification shall never relieve the user from any fees or liability which may be imposed by this ordinance, other regulatory agencies or other applicable law.
- D. Significant industrial users shall notify IRWD immediately of any changes at its site affecting the potential for a slug discharge

8.04 REPORTING OF BY-PASS

- A. By-pass of industrial wastewater through pretreatment equipment to the sewerage facilities is prohibited. Enforcement action may be taken against the user, unless:
 - 1. By-pass was unavoidable to prevent loss of life, personal injury, or severe property damage, and
 - 2. There were no feasible alternatives to the by-pass, such as the use of auxiliary treatment equipment, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate

back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a by-pass which occurred during normal periods of equipment downtime or preventative maintenance, and

3. The user submitted notice as required by this ordinance, or;
 4. The bypass did not exceed user discharge limits and was required for essential maintenance.
- B. If a user knows in advance of the need for a by-pass, it shall submit prior notice to IRWD at least ten (10) days before the date of the by-pass.
- C. IRWD may approve an anticipated by-pass after considering its adverse effects, if IRWD determines that it will meet the conditions listed within this section. A user shall submit notice of an unanticipated by-pass that exceeds their wastewater discharge permit limitation to IRWD within 24 hours from the time the user becomes aware of the by-pass. A written report shall also be provided within five (5) working days of the time the user becomes aware of the by-pass. The report shall contain:
1. Description of the by-pass and its cause.
 2. Duration of the by-pass, including exact dates and times.
 3. Anticipated time it is expected to continue if the by-pass has not been corrected.
 4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the by-pass.
- E. Failure to submit notice and/or written report may be grounds for wastewater discharge permit suspension or revocation. Failure to provide timely notice under Section 804 D. is deemed a waiver of the bypass defense for the user violation.
- F. Such notification shall not relieve the user of any expense, loss, damage, or other liability which may be incurred as a result of damage or loss to sewerage facilities or any other damage or loss to person or property. Such notification shall never relieve the user from any fees or liability that may be imposed by this ordinance, other regulatory agencies or other applicable law.

8.05 BASELINE MONITORING REPORTS (40 CFR 403.12(B))

- A. Within either one hundred eighty (180) days after the effective date of a categorical standard or the final administrative decision on a category determination under 40 CFR 403.6(a)(4), whichever is later, an existing categorical industrial user currently discharging to or scheduled to discharge shall submit to IRWD a report containing the information listed below. At least ninety (90) days prior to commencement of discharge, new sources, and sources that become categorical industrial users subsequent to the promulgation of an applicable categorical standard shall submit to IRWD a report containing the information listed below. A new source shall report the method of pretreatment it intends to use to meet applicable categorical standards. A new source also shall give estimates of its anticipated flow and quantity of pollutants to be

discharged. The baseline monitoring report shall include, but is not limited to, the following:

1. Identifying information. The name and address of the site, including the name of the operator and owner.
2. Permits. A list of any environmental control permits held by or for the site. Description of Operations. A brief description of the nature, average rate of production, and North America Industrial Classification of the operation(s) carried out by such industrial user. This description should include a schematic process diagram which indicates points of discharge to sewerage facilities from the regulated processes.
4. Flow Measurements. Information showing the measured average daily and maximum daily flow, gpd, to sewerage facilities from regulated process streams and other streams as necessary.
5. Measurement of Pollutants. The categorical pretreatment standards applicable to each regulated process and the results and analysis identifying the nature and concentration, and/or mass, where required by the standard or by IRWD, of regulated pollutants in the discharge from each regulated process. Instantaneous, daily maximum, and long-term average concentrations, or mass where required, shall be reported. The sample shall be representative of daily operations. In cases where the standards requires compliance with a BMP or pollution prevention alternative, the industrial user shall submit documentation as required by IRWD or the applicable standards to determine compliance with the standard.
6. Certification. A statement, reviewed by the user's CAR and certified by a qualified professional, indicating whether pretreatment standards are being met on a consistent basis, and if not, whether additional operation and maintenance (O&M) and/or additional pretreatment is required to meet the pretreatment standards and requirements.
7. Compliance schedule. If additional pretreatment and/or O&M will be required to meet the pretreatment standards, the shortest schedule by which the industrial user will provide such additional pretreatment and/or O&M. The completion date in this schedule shall not be later than the compliance date established for the applicable pretreatment standard.
8. Signature and certification. All monitoring reports shall be signed and certified in accordance with Section 802 E. of this ordinance.

8.06 REPORT ON PROGRESS IN MEETING COMPLIANCE SCHEDULES(40 CFR 403.12(C))

- A. All Class I users required to submit compliance schedules shall report their progress no later than fourteen (14) days after each due date contained in their compliance schedule.
- B. The schedule shall contain increments of progress in the form of dates for the commencement and completion of major events leading to the construction and

operation of additional pretreatment required for the user to comply with the applicable pretreatment standards.

- C. No increment referred to above shall exceed nine (9) months.
- D. In no event shall more than nine (9) months elapse between progress reports to IRWD.

8.07 REPORT ON COMPLIANCE WITH CATEGORICAL PRETREATMENT STANDARDS DEADLINE (40 CFR 403.12(D))

- A. Within ninety (90) days following the date for final compliance with the applicable categorical standards or within ninety (90) days of the introduction of wastewater into sewerage facilities, the affected user shall submit a report containing the information listed below. This report shall include, but is not limited to the following:
 - 1. Flow Measurements. Information showing the measured average daily and maximum daily flow, in gallons per day, to sewerage facilities from regulated process streams and other streams.
 - 2. Measurement of Pollutants. The categorical pretreatment standards applicable to each regulated process and the results and analysis identifying the nature and concentration, and/or mass, where required by the standard or by IRWD, of regulated pollutants in the discharge from each regulated process. Instantaneous, daily maximum, and long-term average concentrations, or mass where required, shall be reported. The sample shall be representative of daily operations.
 - 4. Certification. A statement, reviewed by the user's CAR and certified by a qualified professional, indicating whether pretreatment standards are being met on a consistent basis, and if not, whether additional operation and maintenance (O&M) and/or additional pretreatment is required to meet the pretreatment standards and requirements.
 - 5. Signature and certification. All monitoring reports shall be signed and certified in accordance with Section 802 E. of this ordinance.

8.08 PERIODIC COMPLIANCE REPORT

- A. All Class I users subject to federal pretreatment standards (except a non-significant categorical user) as a minimum shall submit reports containing the information required in 40 CFR 403.12 during the months of June and December, or as required in their wastewater discharge permit or other control mechanism.
- B. A Class I user determined to be a non-significant categorical industrial user by IRWD pursuant to Section 2.02.B.86.c. shall annually submit a report containing information as required in their wastewater discharge permit or other control mechanism.
- C. All users may be required to submit periodic compliance reports containing information as required in their wastewater discharge permit, other control mechanism or as required by IRWD.

8.09 RIGHT OF ENTRY

IRWD shall have the right to enter the premises of any user to determine whether the user is complying with the requirements of this ordinance and any individual wastewater discharge permit, other control mechanism or order issued hereunder. Users shall allow IRWD ready access to all parts of the premises for the purpose of inspection, sampling, records examination and copying, and the performance of any other duties.

8.10 ANALYTICAL REQUIREMENTS

- A. All pollutant analyses, including sampling techniques, to be submitted as part of a wastewater discharge permit application or report shall be performed in accordance with the techniques prescribed in 40 CFR
- B. Part 136 and amendments thereto, unless otherwise specified in an applicable categorical pretreatment standard. If 40 CFR Part 136 does not contain sampling or analytical techniques for the pollutant in question, or where the EPA determines that the Part 136 sampling and analytical techniques are inappropriate for the pollutant in question, sampling and analyses shall be performed by using validated analytical methods or any other applicable sampling and analytical procedures, including procedures suggested by IRWD or other parties approved by the EPA.

8.11 SAMPLE COLLECTION

- A. Samples collected by the user to satisfy reporting requirements contained in this ordinance, their wastewater discharge permit or other control mechanism shall be based on data obtained through appropriate sampling and analysis performed during the period covered by the report, based on data that is representative of conditions occurring during the reporting period.
- B. Except as indicated in Section 8.11.C. and 8.11.D. below, the user shall collect wastewater samples using 24-hour flow-proportional composite sampling techniques, unless time-proportional composite sampling or grab sampling is authorized by IRWD. Where time-proportional composite sampling or grab sampling is authorized by IRWD, the samples shall be representative of the discharge. Using protocols specified in 40 CFR 136 and appropriate EPA guidance, multiple grab samples collected during a 24-hour period may be composited prior to the analysis as follows: for cyanide, total phenols and sulfides the samples may be composited in the laboratory or in the field; for volatile organics and oil and grease, the samples may be composited in the laboratory. Composite samples for other parameters unaffected by the compositing procedures as documented in approved EPA methodologies may be authorized by IRWD, as appropriate. In addition, grab samples may be required at any time to show compliance with instantaneous discharge limits.
- C. Samples for analysis of oil and grease, temperature, pH, cyanide, total phenols, sulfides, and volatile organic compounds shall be obtained using grab sample collection techniques.
- D. For sampling required in support of baseline monitoring and 90-day compliance reports required by this ordinance and 40 CFR 403.12(b) and (d), a minimum of four (4) grab samples shall be used for pH, cyanide, total phenols, oil and grease, sulfide and volatile

organic compounds for users for which historical sampling data do not exist; for users for which historical sampling data are available, IRWD may authorize a lower minimum. For reports required by this ordinance and 40 CFR 403.12(e) and (h), the user shall collect the number of grab samples necessary to assess and assure compliance with applicable pretreatment standards and requirements.

8.12 TIMING

Reports shall be deemed to have been submitted on the date postmarked. For reports that are not mailed or delivered with postage prepaid the date of receipt of the report shall govern.

8.13 NOTIFICATION OF CHANGED DISCHARGE

All users that have been issued a wastewater discharge permit shall notify IRWD in advance of any substantial change in the volume or character of pollutants in their discharge in accordance with 40 CFR 403.12(j)

8.14 NOTIFICATION OF THE DISCHARGE OF HAZARDOUS WASTE (40 CFR 403.12(P)(1))

- A. The industrial user shall notify IRWD, the EPA Regional Waste Management Division Director, and State hazardous waste authorities in writing of any discharge into sewerage facilities of a substance, which, if otherwise disposed of, would be a hazardous waste under 40 CFR part 261. Such notification must include the name of the hazardous waste as set forth in 40 CFR Part 261, the EPA hazardous waste number, and the type of discharge (continuous, batch, or other). If the industrial user discharges more than one hundred (100) kilograms of such waste per calendar month to sewerage facilities, the notification shall also contain the following information to the extent such information is known and readily available to the industrial user: An identification of the hazardous constituents contained in the wastes, an estimation of the mass and concentration of such constituents in the wastestream discharged during that calendar month, and an estimation of the mass of constituents in the wastestream expected to be discharged during the following twelve (12) months. All notifications must take place no later than one hundred and eighty (180) days after a discharge to sewerage facilities commences. Any notification under this section need be submitted only once for each hazardous waste discharged. However, notifications of changed discharges must be submitted under Section 813 of this ordinance and as listed in 40 CFR 403.12(j). The notification requirement in this section does not apply to pollutants already reported under the self-monitoring requirements of Sections 8.05, 8.07 and 8.08 of this ordinance and as listed in 40 CFR 403.12(b), (d), and (e).
- B. Dischargers are exempt from the requirements of Section 814. A., above, during a calendar month in which they discharge no more than fifteen (15) kilograms of hazardous wastes, unless the wastes are acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e). Discharge of more than fifteen (15) kilograms of non-acute hazardous wastes in a calendar month, or of any quantity of acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e), requires a one-time notification. Subsequent months during which the industrial user discharges more than such quantities of any hazardous waste do not require additional notification.
- C. In the case of any new regulations under Section 3001 of RCRA identifying additional characteristics of hazardous waste or listing any additional substance as a hazardous

waste, the industrial user must notify IRWD, the EPA Regional Waste Management Waste Division Director, and State hazardous waste authorities of the discharge of such substance within ninety (90) days of the effective date of such regulations.

- D. In the case of any notification made under this section, the industrial user shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical.
- E. This section does not create a right to discharge any substance not otherwise permitted to be discharged by this ordinance, a permit issued thereunder, or any applicable Federal or State law.

ARTICLE 9 ENFORCEMENT

9.01 ENFORCEMENT SCOPE

- A. IRWD finds that in order for it to comply with the laws, regulations, and rules imposed upon it by regulatory agencies and to ensure that sewerage facilities and treatment processes are protected and are able to operate with the highest efficiency, specific enforcement provisions must be adopted to regulate discharges from industrial users.
- B. IRWD is willing to cooperate with all users on improvements in wastewater quality, yet must be in a position to ensure that uncooperative users shall comply with this ordinance and any conditions set forth in a wastewater discharge permit.
- C. IRWD intends to ensure that all interested parties are afforded due process of law and that any noncompliance or violation is resolved as soon as possible. Enforcement shall be guided by the IRWD Enforcement Response Plan (ERP).
- D. All users have a right of appeal pursuant to the procedures set forth in this ordinance.
- E. Each non-compliance or violation per day and each day of noncompliance or violation shall be taken as a separate noncompliance or violation for determining the amount of fees, charges, fines or penalties and/or which enforcement actions may be taken. A violation of a weekly average is considered seven (7) days of violation for that parameter and a violation of a monthly average is based upon the number of days in that month. A violation of multiple parameters caused by a single operational upset is considered one violation.
- F. The issuance or exercise of any type of an enforcement action provided for under this ordinance shall not be a bar against, or a prerequisite for, taking any other or additional enforcement action against a user under this ordinance or any other local, state or federal law. The remedies provided for in this ordinance are not exclusive and IRWD is empowered to take more than one enforcement action against any noncompliant user.

9.02 NOTICE OF NONCOMPLIANCE (NON)

- A. In the event that it is determined that a user is in noncompliance with any provision of this ordinance, or the terms, conditions and limitations of its wastewater discharge permit, IRWD may issue a Notice of Noncompliance (NON), whereby the user shall comply with all directives, conditions and requirements therein within the time prescribed.
- B. The NON may contain terms and conditions including, but not limited to, installation of pretreatment equipment, sampling structures, submittal of drawings or technical reports, payment of fees or administrative fines, limits on rate and time of discharge or any other provisions to ensure compliance with this ordinance and the user's wastewater discharge permit. This action is not a prerequisite to taking other or more severe enforcement actions.

9.03 NOTICE OF VIOLATION (NOV)

- A. In the event that it is determined that a user has not responded to a NON that was previously issued to them or that noncompliance of any pretreatment standards requires their immediate attention, IRWD may issue a Notice of Violation (NOV), identifying the violations and requiring the user to comply with all directives, conditions and requirements therein within the time prescribed.
- B. The NOV may contain terms and conditions including, but not limited to, installation of pretreatment equipment and facilities, submittal of drawings or technical reports, payment of fees, administrative fines, limits on rate and time of discharge or any other provisions to ensure compliance with this ordinance. This action is not a prerequisite to taking other or more severe enforcement actions.

9.04 ADMINISTRATIVE ORDER (AO)

- A. The AO is an enforcement document from IRWD directing the noncompliant user to undertake or to cease specific activities required to bring the user into compliance with this ordinance or the terms, conditions and limitation of a wastewater discharge permit as determined by IRWD. The terms and conditions of the AO are not negotiable by the user. The circumstances of a user's noncompliance may dictate which theme the administrative order takes to achieve the earliest possible return to compliance by the user. AOs may include administrative complaints. Types of AOs may include, but are not limited to, the following:
 - 1. Probation Order (PO)
 - a. The PO directs the noncompliant user to achieve compliance by a date specified in the order. The PO is usually issued when a user is in non-compliance of this ordinance, or the terms, conditions and limitations of its wastewater discharge permit or other enforcement action, or has not made payment of all amounts owed to IRWD which include, but are not limited to, any fees, charges, fines and/or penalties. This action is not a prerequisite to taking other or more severe enforcement actions.
 - 2. Show Cause Order (SCO)

- a. The SCO directs the noncompliant user to appear at a formal meeting, usually at a IRWD location, to explain its noncompliance, and to show cause why more severe enforcement actions against the user should not go forward. This action is not a prerequisite to taking other or more severe enforcement actions.
3. Cease and Desist Order (CDO)
 - a. The CDO directs the noncompliant user to cease illegal or unauthorized discharges immediately, or to terminate its discharge altogether. A CDO may be issued in situations where a particular discharge could cause interference or pass through, or threaten human safety or the environment. The CDO may be issued immediately upon discovery of the problem. In an emergency, a CDO may be issued by any means, however, such an order should be followed by a written CDO on the user,. If necessary, IRWD may order immediate cessation of any discharge to the a sewerage facility, regardless of the user's compliance status. If a user fails to comply with the CDO, IRWD may take any independent action to halt the discharge. This action in not a prerequisite to taking other or more severe enforcement actions.

9.05 WASTEWATER DISCHARGE PERMIT SUSPENSION OR REVOCATION

A. Grounds

1. IRWD may suspend or revoke any wastewater discharge permit when it is determined that a user:
 - a. Violated an administrative order.
 - b. Provided a false statement, representation, record, report or other document to IRWD.
 - c. Refused to provide records, reports, plans or other documents required to determine wastewater discharge permit terms, conditions, or limitations, discharge compliance, or compliance with this ordinance.
 - d. Discharged effluent that causes pass-through or interference with sewerage facilities.
 - e. Falsified, tampered with, or knowingly rendered inaccurate any monitoring device or sample collection method.
 - f. Discharged effluent that endangers human health or the environment.
 - g. Failed to report significant changes in operations or wastewater constituents and characteristics.
 - h. Failed to comply with the terms and conditions of any enforcement action.

- i. Refused reasonable access to the permittee's premises for the purpose of inspection and monitoring.
 - j. Failed to make timely payment of any fees, charges, fines or penalties owed to IRWD.
 - k. Violated any conditions or limitations of its wastewater discharge permit or any provision of this ordinance.
 - l. Discharged batch dumps to sewerage facilities not authorized or permitted by IRWD.
- B. Notice of Wastewater Discharge Permit Suspension/Revocation
 1. When IRWD has reason to believe that grounds exist for suspension or revocation of a wastewater discharge permit, written notice shall be given by certified mail to the user setting forth a statement of facts and grounds deemed to exist together with a description of the time and place where the charge shall be heard by the General Manager. The hearing date shall not be less than fifteen (15) days nor more than sixty (60) days after the mailing of such notice.
- C. Hearing on Permit Suspension/Revocation
 1. At the wastewater discharge permit suspension/revocation hearing, the user shall have an opportunity to respond to the allegations set forth in the notice. The hearing shall be conducted in accordance with procedures established by the General Manager and approved by IRWD's General Counsel.
 2. After the hearing, the General Manager's designee shall submit a written report to the General Manager setting forth a brief statement of facts found to be true, a determination of the issues presented, conclusions, and a recommendation.
 3. Upon receipt of the written report, the General Manager shall make his determination. Should he find that the grounds exist for suspension or revocation of the wastewater discharge permit, he shall issue his decision and order, in writing within thirty (30) days after the hearing by his designee. A copy of the written decision shall be sent by personal delivery or certified mail to the user.
- D. Effect of Wastewater Discharge Permit Suspension
 1. Upon the issuance of an order of suspension by the General Manager, the user shall have no right to discharge any industrial wastewater, directly or indirectly to sewerage facilities for the duration of the suspension. All costs for physically terminating and reinstating service shall be paid by the user.
 2. An order of wastewater discharge permit suspension issued by the General Manager shall be deemed final upon delivery to the user, unless appealed to the Board as specified in Section 913 of this ordinance.
- E. Effect of Wastewater Discharge Permit Revocation

1. On the effective date of a wastewater discharge permit revocation being final, the user shall permanently lose all rights to discharge any industrial wastewater directly or indirectly to sewerage facilities. All costs for physical termination shall be paid by the user.
2. Each owner and employee of the user shall be bound by the order of wastewater discharge permit revocation. Any future application from any user subject to an order of wastewater discharge permit revocation will only be considered by IRWD after fully reviewing the records of revocation. Such records may be the basis for denial of a new wastewater discharge permit.
4. An order of permit revocation issued by the General Manager shall be deemed final upon delivery to the user, unless appealed to the Board as specified in Section 913 of this ordinance.

9.06 TERMINATION OF SERVICE

IRWD may physically terminate water or sewer service to any user that violates or continues to violate the provisions of this ordinance, a term of any order of suspension or revocation of a wastewater discharge permit or other control mechanism. All costs for physical termination shall be paid for by the user as well as all costs for reinstating services.

9.07 EMERGENCY SUSPENSION

- A. IRWD's General Manager may suspend water or sewer service when such suspension is necessary, in order to stop an actual or impending discharge which presents or may present an imminent or substantial endangerment to the health and welfare of persons, to the environment, cause interference to sewerage facilities, or cause IRWD to violate any state or federal law or regulation.
- B. An emergency suspension order is final and has no right of appeal.

9.08 INJUNCTION

Whenever a discharge of wastewater is in violation of the provisions of this ordinance, IRWD may petition the superior court for the issuance of a preliminary or permanent injunction, or both, as may be appropriate to restrain the continuance of such discharge.

9.09 CIVIL FINES AND PENALTIES

- A. Authority.
 1. All users of sewerage facilities are subject to administrative or judicial enforcement actions by IRWD, EPA, State Regional Water Quality Control Board or the District Attorney of Orange County. Actions may be taken pursuant to the authority and provisions of several laws, including but not limited to:
 - a. Federal Water Pollution Control Act (Clean Water Act).
 - b. California Porter-Cologne Water Quality Act (California Water Code).

- c. California Hazardous Waste Control Law.
- d. Resource Conservation and Recovery Act (RCRA).

B. Recovery of Fines or Penalties.

- 1. Payment of fines or penalties by IRWD due to enforcement actions of other regulatory agencies based upon a violation by IRWD whose cause can be established as the discharge of any user which is in violation of any provisions of this ordinance or a wastewater discharge permit shall entitle IRWD to recover from the user all cost and expenses, including, but not limited to the full amount of fines and penalties which IRWD has been subjected to.
- 2. Each violation shall constitute a new and separate violation and shall be subject to the fines and penalties contained herein.

C. Civil Liability

- 1. Pursuant to the authority of California Government Code Sections 54739-54740, any user, permittee, discharger or other person who violates any provision of this ordinance, any wastewater discharge permit condition, prohibition or effluent limitation, or any order, compliance schedule, suspension or revocation shall be civilly liable for a sum not to exceed twenty-five thousand dollars (\$25,000) per violation for each day in which such violation occurs.
- 2. Pursuant to the authority of Act. 33 U.S.C. Section 1251 et seq., any user, permittee, discharger or other person who violates any provision of this ordinance, any wastewater discharge permit condition, prohibition or effluent limitation, or any order, compliance schedule, wastewater discharge permit suspension or revocation shall be civilly liable for a sum not to exceed twenty-five thousand dollars (\$25,000) per violation for each day in which such violation occurs.
- 3. IRWD may petition the superior court to impose, assess and recover penalties or other such penalties as IRWD may impose, assess and recover pursuant to federal and/or state legislative authorization.
- 4. Notwithstanding any other provisions of law, all civil penalties imposed by the court for a violation of this ordinance shall be distributed to IRWD.
- 5. Remedies under this section are in addition to and do not supersede or limit any and all other remedies, civil or criminal, but no liability shall be recovered under this section for any violation for which liability is recovered under Section 909 D. of this ordinance.

D. Administrative Complaint

- 1. Pursuant to the authority of California Government Code Sections 54740.5 and 54740.6, IRWD may issue an administrative complaint to any user, permittee, discharger or other person who violates any provision of this ordinance, any

wastewater discharge permit condition, prohibition or effluent limitation, or any administrative, suspension or revocation order or other control mechanism.

2. The administrative complaint shall be served by personal delivery or certified mail on such person and shall inform the person that a hearing shall be conducted, within sixty (60) days following service. The administrative complaint will allege the act or failure to act that constitutes the violation(s), set forth the provisions of law authorizing civil liability to be imposed and the proposed civil penalty. The matter shall be heard by the General Manager or his designee. The person to whom an administrative complaint has been issued may waive the right to a hearing, in which case a hearing shall not be conducted.
3. At the hearing, the person shall have an opportunity to respond to the allegations set forth in the administrative complaint by presenting written or oral evidence. The hearing shall be conducted in accordance with the procedures established by the General Manager and approved by IRWD's General Counsel.
4. After the conclusion of the hearing, the General Manager's designee shall submit a written report to the General Manager setting forth a brief statement of the facts found to be true, a determination of the issues presented, conclusions and a recommendation. Upon receipt of the written report, the General Manager shall make his determination and should he find that grounds exist for assessment of a civil penalty, he shall issue his decision and order in writing within thirty (30) calendar days after the conclusion of the hearing. If not appealed, the order shall be final thirty-one (31) days after it is served on the person.
5. A person dissatisfied with the decision of the General Manager may appeal to the Board pursuant to Section 9.13 of this ordinance within thirty (30) days of notice of the General Manager's decision.
6. If, after the hearing or appeal, if any, it is found that the person has violated reporting or discharge requirements or other provisions of the this ordinance, the General Manager or Board may assess a civil penalty against that person.
7. In the determination of the amount of the civil penalty, all relevant circumstances may be taken into consideration, including, but not limited to, the extent of harm caused by the violation, the economic benefit derived through any non-compliance, the nature and persistence of the violations, the length of time over which the violation occurs and the corrective action(s), if any, attempted or taken by the person.
8. Civil penalties may be assessed as follows:
 - a. In an amount which shall not exceed two thousand dollars (\$2,000) for each day for failing or refusing to furnish technical or monitoring reports.
 - b. In an amount which shall not exceed three thousand (\$3,000) for each day for failing or refusing to timely comply with any compliance schedule
 - c. In an amount which shall not exceed five thousand dollars (\$5,000) per violation for each day for discharges in violation of any waste discharge

limitation, wastewater discharge permit condition, other control mechanism or requirement issued, reissued or adopted by IRWD.

- d. In an amount which does not exceed ten dollars (\$10) per gallon for discharges in violation of any suspensions, cease and desist order or other orders, or prohibition issued, reissued or adopted by IRWD.
9. Payment of civil penalties shall be due within thirty (30) days of the date of the order assessing the penalties becomes final. The amount of any administrative civil penalties imposed which have remained delinquent for a period of sixty (60) days from the date they are due shall constitute a lien against the real property of the discharger from which the discharge resulting in the imposition of the penalty originated. The lien shall have no force and effect until recorded with the county recorder and when recorded shall have the force and effect and priority of a judgment lien and continue for ten (10) years and be renewable in accordance with law.
10. Copies of the administrative order shall be served by personal service or by registered mail upon the party served with the administrative complaint and upon other persons who appeared at the hearing and requested a copy of the order.
11. Any party aggrieved by a final order issued by the Board after granting review of the order of the General Manager may obtain review of the order of the Board in the Superior Court, by filing in the court a petition for writ or mandate within thirty (30) days following the service of a copy of the decision and order issued by the Board.
12. Any party aggrieved by a final order issued by the General Manager, for which the Board denies review, may obtain review of the order of the General Manager in the Superior Court, by filing in the court a petition for writ of mandate within thirty (30) days following service of a copy of a decision and order denying review by the Board.
13. No administrative civil penalties shall be recoverable under this section for any violation for which civil liability is recovered under Section 9.09.C. of this ordinance.

9.10 CRIMINAL PENALTIES

- A. Any person who violates any provision of this ordinance is guilty of a misdemeanor, which upon conviction is punishable by a fine not to exceed one thousand dollars (\$1,000) or imprisonment for not more than thirty (30) days or both.
- B. Each violation shall constitute a new and separate violation and shall be subject to the penalties contained herein.

9.11 PUBLIC NUISANCE

- A. Discharge of wastewater in a manner that is in noncompliance or violation of this ordinance or of any order issued by IRWD, in accordance with this ordinance, shall

hereby be declared a public nuisance and shall be corrected or abated as directed by IRWD.

- B. Any person creating a public nuisance is guilty of a misdemeanor and is subject to the criminal penalties identified in Section 9.10 of this ordinance.

9.12 APPEALS TO THE GENERAL MANAGER

A. General

1. Any user affected by a decision, action or determination made by IRWD staff may file with the General Manager a written request for an appeal hearing.
2. Request must be made within fifteen (15) days of the mailing of the original decision.
3. Request for hearing shall set forth details of all facts supporting the appellant's request for hearing.

B. Notice

1. The General Manager shall, within fifteen (15) days of receiving the request for appeal provide written notice to the user of the hearing date, time, and place.
2. The hearing time shall not be more than thirty (30) days from the mailing of such notice by certified mail to the appellant unless a later date is agreed to by the appellant.
3. If the hearing is not held within the time set due to actions of the appellant, then IRWD's decision shall be deemed final.

C. Hearing

1. The appellate shall have the opportunity to present information supporting its position concerning IRWD's original decision, action or determination.
2. The hearing shall be conducted in accordance with procedures established by the General Manager and approved by IRWD's General Counsel.

D. Written Determination

1. After the hearing the General Manager shall make a determination whether to uphold, modify or reverse original decision, action or determination as issued by IRWD staff.
2. This decision shall be put into writing within a brief statement of facts found to be true, the determination of the issues presented, and the findings.
3. The final determination of the General Manager upon his approval shall be executed as the order.
4. A copy shall be mailed or delivered to the appellant.

5. The order of the General Manager shall be final in all respects fifteen (15) days after it is mailed to the appellant, unless appealed under Section 9.13 of this ordinance.

E. Wastewater Discharge Permit Suspension/Revocation Appeals

1. Appeals regarding wastewater discharge permit suspension or revocation are covered under Section 9.05 and Section 9.13 as specified in this ordinance.

9.13 APPEALS TO THE BOARD

A. General

1. The user may, within thirty (30) days after the date of notification of the General Manager's order upholding IRWD's determination, file a written appeal to the Board.
2. A fee of one hundred dollars (\$100) shall accompany the written appeal which shall be refunded if the Board of Directors reverses or modifies the order of the General Manager.
3. A request for appeal to the Board shall set forth details of the past record and that new arguments cannot be raised on appeal to the Board that could have been, but were not, raised in the prior appeal to the General Manager.
4. Pending the hearing on appeal, the user shall not be entitled to discharge into sewerage facilities beyond the effective date of the original order determined by the General Manager, unless it has been determined by the General Manager that the user is pursuing good faith arguments and approves such discharge.

B. Notice

1. The Board Secretary, within fifteen (15) days of receiving the request for appeal, will provide written notice to the user of the hearing date, time and place.
2. The hearing date shall not be more than forty-five (45) days from the mailing of such notice by certified mail to the appellate unless a later date is agreed to by the appellant.
3. If the hearing is not held within the time set due to action of the appellant, the General Manager's decision shall be deemed final.

C. Hearing

1. The appellant shall have the opportunity to present information supporting its position concerning the General Manager's determination.
2. The hearing shall be conducted in accordance with procedures established by the Board and approved by IRWD's General Counsel.

D. Written Determination

1. After the hearing, the Board shall make a determination whether to uphold, modify or reverse the original decision, action or determination as ordered by the General Manager.
2. The decision of the Board shall be reduced to writing within thirty (30) days after the hearing.
3. It shall contain a brief statement of facts found to be true, the determination of the issues presented, and the findings. The decision shall be submitted to the appellant.
4. The order of the Board shall be final upon its adoption.

9.14 JUDICIAL REVIEW

A. Purpose and Effect

1. Pursuant to Section 1094.6 of the California Code of Civil Procedure, the time in which a user may bring an administrative mandamus action shall be limited to ninety (90) days following the final decision in the adjudicative administrative hearing in question.

B. Time Limit for Judicial Review

1. Judicial review of any decision of IRWD's Board may be made pursuant to Section 1094.5 of the California Code of Civil Procedure only if the petition for writ of mandate is filed no later than ninety (90) days following the date on which any decision becomes final.

C. Preparation of Record

1. The complete record of the proceedings shall be prepared by IRWD and shall be delivered or mailed to the petitioner within one hundred-ninety (190) days after petitioner has filed a written request.
2. Petitioner shall pay IRWD for IRWD's actual costs for preparing and transcribing the record.

D. Extension

1. If the petitioner files a request for the record within ten (10) days after the date the decision becomes final, the time within which a petition may be filed, pursuant to Section 1094.5 of the California Code of Civil Procedure, shall be extended to no later than thirty (30) days following the date on which the record is delivered or mailed, by IRWD, to the petitioner or the petitioner's attorney of record, if appropriate.

E. Notice

1. In making a final decision, IRWD shall provide notice to the user whose wastewater discharge permit has been denied, suspended or revoked, that the

time in which judicial review must be sought is governed by Section 1094.6 of the California Code of Civil Procedures.

- F. This section does not apply to action taken under Section 9.09 of this ordinance.

9.15 PAYMENT AND COLLECTION OF FEES AND CHARGES

- A. Except as otherwise provided, all fees and charges are due and payable upon receipt of an invoice or notice thereof. All such amounts are delinquent if unpaid forty-five (45) days after date of invoice or notice.
- B. Any invoice or notice that becomes delinquent may have added to it an assessment in accordance with the following:
 - 1. Forty-six (46) days after the date of invoice or notice, an assessment of ten percent (10%) of the base amount, not to exceed a maximum of \$1,000.
 - 2. Ninety (90) days after the date of invoice or notice, a total of twenty-five percent (25%) of the base amount, not to exceed a maximum of \$2,500.
- C. Any invoice or notice that is outstanding and unpaid after ninety (90) days may be cause for immediate initiation of wastewater discharge permit revocation proceedings or immediate wastewater discharge permit suspension.
- D. Delinquent assessments under this section may not accrue to those invoices or notices successfully appealed, provided IRWD received written notice of appeal prior to the payment due date.
- E. Payment of disputed fees and charges are still required by the due date during review of any appeal submitted by permittee.
- F. This section does not apply to Section 9.09 of this ordinance.

9.16 RECOVERY OF ENFORCEMENT COSTS

In the event a user fails to comply with any of the terms and conditions of this ordinance, wastewater discharge permit, administrative order, wastewater discharge permit suspension or revocation, other control mechanism or any other enforcement action, IRWD shall be entitled to reasonable attorney's fees and costs which may be incurred during enforcement of any terms and conditions with or without filing proceedings in court.

9.17 FINANCIAL SECURITY CONDITIONS

- A. Compliance Deposit
 - 1. Users that have been subject to enforcement actions and/or fees, charges, penalties or fines may be required to deposit with IRWD an amount determined by the General Manager as necessary to guarantee payment of all charges, fees, costs and expenses that may be incurred in the future.

2. A compliance deposit shall be received by IRWD before IRWD either issues a wastewater discharge permit, other control mechanism or grants the user permission for further discharge to sewerage facilities.
- B. Delinquent Accounts
1. Any user who fails to make payment in full of all fees, charges, penalties or fines assessed by IRWD including reconciliation amounts, delinquency fees, and other costs or fees may be required to obtain the issuance of an amendment to their wastewater discharge permit.
- C. Bankruptcy
1. Any user filing any legal action in any court of competent jurisdiction, including the United States Bankruptcy Court, for purposes of discharging its financial debts or obligations or seeking court-ordered protection from its creditors, shall within ten (10) days of filing such action, apply for and obtain the issuance of an amendment to its wastewater discharge permit by IRWD.
- D. Wastewater Discharge Permit Amendments
1. An amendment issued to the user's wastewater discharge permit shall be in accordance with the provision of this ordinance.
- E. Security Deposit
1. An amendment to a wastewater discharge permit issued in accordance with this ordinance may be conditional upon the permitted user depositing financial security in an amount equal to the total fees and charges from the preceding year.
 2. Such a deposit shall be used to guarantee payment of all fees and charges incurred for future services and sewerage facilities provided by IRWD and shall not be used by IRWD to recover outstanding fees and charges incurred prior to the user filing and receiving protection from creditors in the United States Bankruptcy Court.
- F. Return of Security Deposit
1. If the user makes full payment in time of all fees and charges incurred over a period of two (2) years following the issuance of an amendment to the user's wastewater discharge permit prescribed by this ordinance, the user's security deposit shall be returned or credited to the user's account.

9.18 REPORT OF ANALYSIS

All collected data from inspection and monitoring sampling conducted by IRWD may be reported to the user. This data, if given to the user, shall be kept by the user and IRWD and made available during inspections by IRWD or any other regulatory agency.

9.19 DAMAGE TO FACILITIES OR INTERRUPTION OF NORMAL OPERATIONS

- A. When a discharger of wastes causes an obstruction, interference, damage, or other impairment to sewerage facilities or to the operation of sewerage facilities, IRWD may assess the costs against the user for the work required to clean, replace or repair the sewerage facility together with expenses incurred to resume normal operations. This shall also be grounds for wastewater discharge permit revocation. A service charge of twenty-five percent (25%) of costs shall be added to the costs and charges to cover IRWD's overhead, including administrative personnel and record keeping. The total amount shall be payable within forty-five (45) days of invoicing by IRWD.
- B. If it can be shown that the discharge by any user is the cause of IRWD violating its NPDES permit and pretreatment requirements established by any Regulatory Agency or incurring additional expenses or suffering losses or damage to IRWD sewerage facilities, then that user shall be responsible for any costs, expenses, or assessments incurred by IRWD, made by other agencies or a court.
- C. Where two or more dischargers cause a single and indivisible harm to sewerage facilities, each is jointly and severally liable for the damages. The burden of proof is on the dischargers to demonstrate that the harm is divisible.

9.20 INDUSTRIAL WASTE PASS THROUGH

- A. If an industrial waste discharge results in a "pass through" event in sewerage facilities, all costs associated with the event, including but not limited to treatment costs, fines, regulatory fines, and other indirect costs may be charged against the user.
- B. The user shall submit plans which prevent future recurrences to the satisfaction of IRWD.
- C. A second occurrence shall be grounds for wastewater discharge permit revocation without the right of appeal.

9.21 BATCH DUMPS

- A. When IRWD determines that a user has discharged concentrated noncompatible wastes into a sewerage facility in a manner or method that is not approved by IRWD, any enforcement action may be taken as set forth in this ordinance.
- B. The user shall be subject to wastewater discharge permit suspension or revocation in accordance with this ordinance as well as any other legal enforcement penalties or remedies available to IRWD.

9.22 PUBLICATION OF USERS IN SIGNIFICANT NONCOMPLIANCE (SNC)

- A. To comply with the requirements of 40 CFR 403, IRWD shall annually publish the names of all industrial users that are in SNC (per Section 202 of this ordinance) of federal pretreatment standards.
- B. Publication of this SNC notice shall be in the newspaper of general circulation that provides meaningful public notice within the IRWD service area tributary to SOCWA.

**ARTICLE 10
FEES AND CHARGES**

10.01 APPLICATION FEE

- A. All application fees shall be in an amount as established by IRWD.
- B. Payment of the application fee must be received before the issuance of a new or renewal of a wastewater discharge permit.
- C. User shall pay any delinquent invoices in full, prior to the wastewater discharge permit renewal.

10.02 ANNUAL WASTEWATER DISCHARGE PERMIT FEE

- A. The annual wastewater discharge permit fee shall be in an amount as established by IRWD.
- B. The annual wastewater discharge permit fee shall be due on or before the date set by IRWD.

10.03 INSPECTION, MONITORING AND SAMPLING CHARGES

Any and all costs incurred by IRWD to inspect, monitor and sample a user for the purpose of assuring compliance with this ordinance, the user's wastewater discharge permit, other control mechanism or other regulations shall be paid for by the user only upon receipt of an invoice or bill from IRWD or its representative.

10.04 DELINQUENCY FEES

- A. Any fees that become delinquent may have added to it an amount as set forth in Section 9.15 of this ordinance.
- B. Any delinquent fee and all assessments including court costs and legal fees thereon may be collected by lawsuit in the name of IRWD.

10.05 ADDITIONAL FEES AND CHARGES

- A. The user will be required to pay all applicable additional fees and charges that are established by IRWD only upon receipt of an invoice or bill.
- B. Any wastewater discharge permit issued for a location where the user is not the property owner, may be conditioned upon depositing financial security to guarantee payment of all additional fees and charges to be incurred, in accordance with the provisions of Section 9.17 of this ordinance.

10.06 RECORDING OF FEES AND CHARGES

- A. IRWD shall keep a permanent record and account of all fees and charges received under this ordinance.
- B. Record information shall include, but is not limited to:

1. Name and address of user.
2. Date and amount of fee or charge.
3. Purpose for which fees or charges were paid.

ARTICLE 11 SEVERABILITY

11.01 SEVERABILITY

- A. If any provisions of this ordinance or the application thereof to any users or circumstances is held invalid, unenforceable, or unconstitutional by any court of competent jurisdiction, the remainder of this ordinance or the application of such provision to other users or other circumstances shall not be affected.
- B. If any section, subsection, clause or phrase of this ordinance is for any reason held to be invalid, unenforceable or unconstitutional by any court of competent jurisdiction, such decision shall not affect the remaining portions of this ordinance. The Board declares that it would have passed said ordinance by section, subsection, sentence, clause or phrase thereof.

ARTICLE 12 REPEAL

12.01 REPEAL

- A. Ordinance No. 2015-01 is hereby repealed in its entirety.
- B. All ordinances or parts of ordinances inconsistent with this ordinance are hereby repealed to the extent that they are inconsistent with the provisions of this ordinance.

ARTICLE 13 EFFECTIVE DATE

13.01 EFFECTIVE DATE

This ordinance becomes effective thirty (30) days after adoption. The Secretary of IRWD is directed to certify to the adoption of this ordinance and to cause a summary hereof to be published in a newspaper of general circulation as required by law.

PASSED AND ADOPTED by the Board of Directors of the Irvine Ranch Water District on
November 23, 2020.

IRVINE RANCH WATER DISTRICT

Dated 11/23/2020 by


President

Dated 11/23/20 by


Secretary